




PRESENTATION
For
CII GBC NATIONAL ENERGY AWARD
FOR
EXCELLENCE IN ENERGY MANAGEMENT



Rashtriya Ispat Nigam Limited
VISAKHAPATNAM STEEL PLANT

TEAM MEMBERS

Sudhanshu Kumar, Sr. Mgr.(EMD)

Rishi Agarwal, Sr. Mgr.(O)-Utilities

Shubham Singh, Dy. Mgr(O)-MMSM

K SUDHAKAR, GM(O)-EMD

(Designated Energy Manager)

CONTENTS



- **Company Profile**
- **Process Flow**
- **Sp. Energy Consumption in last three years**
- **Bench marking(Global and National Bench Marking)**
- **Energy Saving projects implemented in FY 2019-20**
- **Energy Saving projects implemented in FY 2020-21**
- **Energy Saving projects implemented in FY 2021-22**
- **Innovative Projects**
- **Utilization of Renewable Energy Sources**
- **Utilization of Waste as a fuel**
- **GHG Inventorisation**
- **Team Work , Employee Involvement & Monitoring**
- **Energy Management System (ISO:50001)**
- **Learning from CII Award**
- **Awards**
- **Conclusion**

RINL Corporate Structure

Rashtriya Ispat Nigam Limited

Operating Units

Visakhapatnam Steel Plant

Madharam mines Dolomite

Jaggyyapeta mines Limestone

Garbham Manganese

Subsidiary company (51% stake)

Eastern Investment Limited

Orissa Mineral Development Corp. (OMDC)

Bisra Stone Lime Co. Ltd. (BSLC)

Units on Anvil


Transmission Line Towers Plant

Wheel Plant

RINL – Growth Plan

- RINL's completed Upgradation & Modernization for 7.3 MTPA of Crude Steel.
- Products includes bars, rods, wire rod and structural's and Value Added Products
- Vision envisages growth to 20 Mtpa by 2032-33 in phases

Turnover (2021-22)- 28082 INR Cr



Major Accreditations

The 1st ISP to be certified for Quality, Health & Safety and Environment


1st Steel Plant to get ISO 50001 certification for Energy Management

1st Steel PSE to sign Integrity Pact of Transparency International

CMMI Level 3 certification for IT Systems and ISO 27001 for ISMS

1st ISP to be 5S Certified for the whole plant






- Sinter Plant with NEDO
- CO Battery with Coke Dry Quenching and Back Pressure Turbine Station.
- BFs with Gas Expansion Turbine & Top Recovery Turbine station.
- SMS-1 & 2 with LD gas recovery plant.
- Continuous Bloom & Billet caster.




Power Generation capacity from Waste Energy (MW)

Power Generation capacity from Waste Energy (MW)




| | |
|---|-----------------|
| Total Installed capacity: | 541.6 MW |
| Total Power Gen from Waste Energy incl Solar | 337.6 MW |
| % of Power Generation through Waste Energy: | 63.3% |


Energy Consumption Overview



Sp. Energy Consumption-Gcal/tCS




International Bench Marking of SEC(Gcal/tCS)



Bench Marking with Nippon Steel(2020-21)

| Energy(2020-21) | | GHG Emission | | Gap :0.28 Gcal/tCS |
|-----------------|------|--------------|------|---|
| RINL | NSC | RINL | NSC | |
| 6.02 | 5.74 | 2.60 | 2.09 | <p>1) Scrap usage : 200 kg/thm(As per Japanese Industry)-RINL: 80 kg/tCS</p> <p>2) All Energy Conservation technologies Coke Dry Quenching, Top Pressure Recovery Turbine, BOF Gas Recovery, Sinter Cooler waste heat recovery Pulverized Coal Injection, BF stoves Heat Recovery, Billet Caster, Hot Charging, Regenerative Burners, Coal Moisture Control Sensible Heat recovery from BOF gas</p> <p>3) Waste Plastics Injection and tires(0.2 million tons-6 kg/tCS)</p> <p>4) Petro fuel 16 lts/Tcs</p> |

Benchmarking of Energy Consumption-Gcal/tCS



| Energy(2020-21) | | GHG Emission | | Gap :0.38Gcal/tCS |
|-----------------|------------|--------------|------------|--|
| RINL | Tata Steel | RINL | Tata Steel | 1)Coal Injection of >180 kg/tHM (0.250Gcal/tCS) Vs 100 kg/tCS 2) Plant Production: 10 Mt Crude Steel. |
| 6.02 | 5.64 | 2.60 | 2.43 | |

Energy Saving projects implemented in last three years with investment (2019-20)

| S.No. | Title of Project | Energy Savings in | | Investment (Rs Million) |
|-------|---|-------------------|-------------|-------------------------|
| | | Gcal/MKwh | Rs Millions | |
| 1 | Improvement in Power Generation at GETS from 1.07 MW to 3.37 MW | 20 | 142 | 5 |
| 2 | Improvement in Power Generation at TRT from 5.39 MW to 6.80 MW | 12 | 87 | 10 |
| 3 | Increasing Hot Blast Temperature of BF 1 &2 by Inter Connection of Turbo Blowers-4 to BF-1&2 cold blast line at Captive Power Plant-1 | 67752 | 188 | 147 |
| 4 | Modified Pass Design for Round 75 Rolling at MMSM | 0.10 | 0.71 | 0.02 |

Energy Saving projects implemented (2019-20)

| S.No. | Title of Project | Energy Savings in | |
|-------|---|-------------------|-------------|
| | | Gcal/MKwh | Rs Millions |
| 1 | Improvement in Pulverized coal injection at BF-2 from 27.8 to 107.2 Kg/tHM at Blast Furnace | 223830 | 308 |
| 2 | Improvement in LD gas yield at SMS-1 from 104 to 109 Ncum/tCS | 22457 | 31 |
| 3 | Reduction in Coke Breeze consumption at SP-1 from 54.8 kg/tGS to 53.5 Kg/tGS | 38888 | 54 |
| 4 | Reduction in BF Fuel rate from 541.6 kg/tHM to 538.9 kg/tHM | 95237 | 131 |
| 5 | Enhanced argon production by increasing argon recovery from Air Separation Unit-5 | 0.16 | 70 |

ENCON Projects with Investment (2020-21)

| S.No. | Title of Project | Energy Savings in | | | Investment (Rs Million) |
|-------|--|-------------------|------|----------------|----------------------------|
| | | | Unit | Rs Millions | |
| 1 | Interconnection of LD Gas holder -1&2 | 99150 | Gcal | 128 | 8 |
| 2 | Improvement in Power Generation at GETS from 3.37 MW to 6.16 MW | 24.4 | Mkwh | 174 | 5 |
| 3 | Improvement in Power Generation at SHRPP from 0.15 MW to 2.49 MW | 20.5 | Mkwh | 146 | 10 |
| 4 | Installation of 0.5MW roof top solar power plant | 0.14 | Mkwh | 1.01 | RESCO model |

ENCON Projects with no Investment (2020-21)

| S.No. | Title of Project | Energy Savings in | |
|-------|--|-------------------|-------------|
| | | Gcal/MKwh | Rs Millions |
| 1 | Reduction in Sp. Power Consumption at SP-2 from 64.07 to 62.85 Kwh/tGS | 2.8 | 20 |
| 2 | Reduction in Sp. Heat Consumption at SP-1 from 27 to 26 Mcal/tGS | 4080 | 5 |
| 3 | Reduction in Sp. Power Consumption at SP-1 from 64.95 to 63.03 Kwh/tGS | 7.8 | 56 |
| 4 | Improvement in Pulverized coal injection at Blast Furnace-1 from 33.36 to 104 Kg/tHM | 256953 | 331 |
| 5 | Reduction in fuel rate at Blast Furnace-3 from 530.6 to 526.5 Kg/tHM | 29537 | 38 |

ENCON Projects with no Investment (2020-21)

| S.No. | Title of Project | Energy Savings in | |
|-------|---|-------------------|-------------|
| | | Gcal/MKwh | Rs Millions |
| 6 | Reduction in Sp. Heat Consumption at SMS-2 from 45 to 35 Mcal/tCS | 23544 | 30 |
| 7 | Reduction in Sp. Power Consumption at SMS-2 from 119.26 to 113.06 Kwh/tCS | 14.6 | 104 |
| 8 | Reduction in Sp. Heat Consumption at CRMP-1 from 1380 to 1329 Mcal/tGL | 13668 | 18 |
| 9 | Reduction in Sp. Power Consumption at CRMP from 55.17 to 41.82 Kwh/tGL | 7.27 | 52 |
| 10 | Reduction in Sp.Power Consumption at WRM from 120.07 to 118.59 Kwh/tBI | 1.12 | 8 |

ENCON Projects with no Investment (2020-21)



| S.No. | Title of Project | Energy Savings in | |
|-------|---|-------------------|-------------|
| | | Gcal/MKwh | Rs Millions |
| 11 | Reduction in Sp. Heat Consumption at WRM-2 from 260 to 247 Mcal/tBI | 5756 | 7 |
| 12 | Reduction in Sp.Power Consumption at WRM-2 from 211.30 to 200.46 Kwh/tBI | 4.8 | 34 |
| 13 | Reduction in Sp. Heat consumption at BF from 494 Mcal/tHM to 491 Mcal/tHM | 14045 | 18 |

ENCON Projects with Investment (2021-22)



| S.No. | Title of Project | Energy Savings in | |
|-------|---|-------------------|-------------|
| | | Gcal/MKwh | Rs Millions |
| 1 | Reduction in Power Consumption during Deriming at Air Seperation Unit-5 | 0.78 | 0.13 |
| 2 | Hydraulic Modfication in MMSM reheating furnace | 15785 | 1.0 |
| 3 | Reduction in power Consumption by reducing idle running of Stelmor Blowers at Wire Rod Mill | 1.06 | 0.10 |

ENCON Projects with no Investment (2021-22)



| S.No. | Title of Project | Energy Savings in | |
|-------|---|-------------------|-------------|
| | | Gcal/MKwh | Rs Millions |
| 1 | Improvement in tar yield at coke oven from 3.07% to 3.09% | 3884 | 5 |
| 2 | Reduction in coke breeze consumption at Sinter Plant from 71.6 Kg/t charged sinter to 64.2 Kg/t charged Sinter. | 403953 | 541 |
| 3 | Reduction in Sp. Heat Consumption of Sinter Plant-2 from 12 Mcal/tGS to 11 Mcal/tGS. | 3285 | 4 |
| 4 | Reduction in Sp. Power Consumption of Sinter Plant-1 from 63.03 Kwh/tGS to 62.13 Kwh/tGS. | 4.25 | 32 |
| 5 | Increasing in Pulverized Coal Injection (PCI) in Blast Furnace-2 from 82.9 Kg/tHM to 100.3 Kg/tHM. | 150692 | 202 |
| 6 | Reduction in Sp. Power Consumption of Blast Furnace-3 from 50.41 Kwh/tHM to 42.27 Kwh/tHM. | 10.5 | 80 |
| 7 | Improvement in LD gas yield at SMS from 81 Ncum/tCS to 92 Ncum/tCS. | 106526 | 143 |
| 8 | Reduction in Sp. Heat Consumption of SMS-1 from 38 Mcal/tCS to 31 Mcal/tCS. | 18760 | 25 |
| 9 | Reduction in Sp. Heat Consumption of SMS-2 from 35 Mcal/tCS to 33 Mcal/tCS. | 5184 | 7 |

ENCON Projects with no Investment (2021-22)




| S.No. | Title of Project | Energy Savings in | |
|-------|---|-------------------|-------------|
| | | Gcal/MKwh | Rs Millions |
| 10 | Reduction in Sp. Power Consumption of SMS-2 from 113.06 Kwh /tCS to 109.70 Kwh /tCS. | 8.71 | 66 |
| 11 | Reduction in Sp. Power Consumption of Bar Mill from 72.91 Kwh /tIP to 67.81 Kwh /tIP. | 4.33 | 33 |
| 12 | Reduction in Sp. Heat Consumption of Special Bar Mill from 323 Mcal /tIP to 306 Mcal/tIP | 7260 | 10 |
| 13 | Reduction in Sp. Power Consumption of Special Bar Mill from 115.35 Kwh /tIP to 109.02 Kwh /tIP. | 2.70 | 21 |
| 14 | Reduction in Sp. Power Consumption of WRM-2 from 200.46 Kwh /tIP to 193.31 Kwh /tIP | 3.62 | 28 |
| 15 | Reduction in Sp. Power Consumption of MMSM from 91.67 Kwh /tIP to 76.08 Kwh /tIP. | 11.19 | 85 |
| 16 | Reduction in Sp. Heat Consumption of STM from 335 Mcal /tIP to 309 Mcal /tIP. | 10730 | 14 |
| 17 | Reduction in Sp. Power Consumption of STM from 106.79 Kwh /tIP to 96.38 Kwh /tIP. | 0.01 | 0.08 |
| 18 | Reduction in Sp. Power Consumption of CRMP from 41.82 Kwh /tGL to 35.28 Kwh /tGL. | 4 | 32 |

ENCON Projects with no Investment (2021-22)

| S.No. | Title of Project | Energy Savings in | |
|-------|--|-------------------|-------------|
| | | Gcal/MKwh | Rs Millions |
| 19 | Reduction in Sp. Heat Consumption of CRMP-1 from 1329 Mcal /tGL to 1220 Mcal /tGL. | 23418 | 31 |
| 20 | Reduction in Sp. Heat Consumption of CRMP-2 from 951 Mcal /tGL to 909 Mcal /tGL. | 18020 | 24 |
| 21 | Improvement in power generation in BPTS from 7.54 MW to 10.91 MW | 29.52 | 224 |
| 22 | Improvement in power generation in COB-4&5 from 7.95 MW to 15.79 MW. | 68.68 | 521 |
| 23 | Reduction in BF Gas bleeding from 10.28 % to 6.64 %. | 306383 | 410 |

Summary of the Projects identified & Implemented

| YEAR | No of Projects | Thermal Savings (Gcals) | Electrical Savings (Million KWH) | Savings in Rs.Cr | Investment In Rs Cr | Savings (GcaltCS) |
|---------|----------------|-------------------------|----------------------------------|------------------|---------------------|-------------------|
| 2019-20 | 25 | 621918 | 75.64 | 155.3 | 16.2 | 0.17 |
| 2020-21 | 17 | 446733 | 83.54 | 117 | 2.3 | 0.104 |
| 2021-22 | 26 | 1073878 | 149.64 | 257.3 | 0.123 | 0.272 |



INNOVATIVE PROJECTS IMPLEMENTED

| Name of the Project | Replicability | Impact on SEC (Gcal/tCS) | Annual Savings | Investment |
|---|---------------|-----------------------------|----------------|----------------|
| | | | (Rs. In lakhs) | (Rs. In lakhs) |
| Reduction in Power Consumption during Deriming at Air Separation Unit-5 | Yes | 0.0004 | 219 | 1.3 |
| Hydraulic Modification in MMSM reheating furnace | Yes | 0.003 | 211 | 10 |
| Reduction in power Consumption by reducing idle running of Stelmor Blowers at Wire Rod Mill | Yes | 0.001 | 162 | 1.0 |

INNOVATIVE PROJECT-1

Reduction in Power Consumption during Deriming at Air Separation Unit-5

Air Separation Plant produces Oxygen, Nitrogen and Argon in gas and liquid form by cryogenic-distillation process.

ASU-5 consists of Feed air Compressors (1 No.s), Nitrogen compressors (2 No.s), Expansion Turbines (2 No.s), Cryogenic pumps etc.

Main consumers of ASU-5 are Blast furnace, Steel melt shop, Coke Oven, Mills etc.

INNOVATIVE PROJECT-1

Reduction in Power Consumption during Deriming at Air Separation Unit-5


- Cryogenic systems are warmed with hot, dry and purified air to remove moisture and hydrocarbons.
- Prior to the the warm (more than 48 hours old) start up of ASU-5, deriming has to be done to ensure the unit is free of moisture and hydrcoarbons.
- Demand of deriming air is very low (5000 Nm³/hr to 8000 Nm³/hr) for which Air compressor is running at low load.
- Air compressor along with auxiliaries consumes 8.7 MWH of energy to provide deriming air.

INNOVATIVE PROJECT-1

MODIFICATION:

- 1. After a lot of brainstorming and discussions, It is planned to use nitrogen in place of air for deriming process as surplus nitrogenis available in network. .**
- 2. A tapping from existing 9 KScg Nitrogen purge header is taken and connected to the upstream of deriming inlet valve.**
- 3. Now whenever deriming is required to be done, Nitrogen isolation valve is opened and nitrogen is used for deriming.**

Schematic layout of modification



BENIFITS

| S.No | Parameters | Unit | Before innovation | After innovation |
|------|---|--------------|-------------------|------------------|
| 1 | Energy Consumption for deriming annually (MWH) | MWH | 783 | 180 |
| 3 | Cost of deriming annually in lakhs | Lakhs | 216.85 | 14.04 |
| 4 | Unit downtime annually in hours | Hours | 168 | 132 |

Savings: 2.03 Crores per year

INNOVATIVE PROJECT-2

Hydraulic Modification in MMSM reheating furnace

FURNACE DETAILS

- NUMBER OF FURNACES 2
- CAPACITY EACH FURNACE 130 TONS/HR
- NUMBER OF ZONES 5
- HEATING ZONES 1,2,3
- SOAKING ZONES 4,5
- DIMENSIONS 21.7X14.51Mtrs
- EFFECTIVE DIMENSIONS 20X12 Mtrs
- EFFECTIVE AREA 240 M2

INNOVATIVE PROJECT-2

Need of Modification

- Furnace heating capacity is 130t/hr (46 blooms/hr)
- During the single furnace operation not able to roll more than 130 Tons/hr even mills rolling capacity is 260 Tons/hr.
- If discharging rate is more than 130 Tons/hr (46 blooms/hr), blooms are not getting fully soaked.
- Improper soaking results in high power consumption, cobbles and fast wear out of rolls.

INNOVATIVE PROJECT-2

Modification


After discussion, the following options emerged,

| Option | Feasible/not feasible |
|---|---|
| Increase the calorific value of mixed gas | not feasible (require more coke oven gas) |
| Oxygen enrichment | not feasible |
| Decreasing space between blooms | Feasible by decreasing the hydraulic stroke from 400mm to 380 mm |

INNOVATIVE PROJECT-2

BENEFITS

- Increased flue gas resistance due to higher retention time.
- Increase in cycles from 50 to 53 resulted in blooms retention time by 10 minutes.
- Furnace holding capacity increased by 10 blooms.
- 56 blooms discharged in one hour with proper soaking in structural rolling
- Decrease in load in stand -2
- All problems associated with improper soaking in mill eliminated.



| Object Tree | Comment | Cursor1 | Minimum | Maximum | Average | Std Deviation | Cursor1 Time |
|------------------------|-------------------------|-----------|-----------|-----------|-----------|---------------|---------------------|
| Pane1 | | | | | | | |
| F1_F1_AIR_FLOW_TOT_CUM | FURNACE1 AIR TOTAL FLOW | 57,967.72 | 57,921.98 | 57,968.19 | 57,944.37 | 14.65 | 01-08-2022 19:58:16 |
| F1_F1_GAS_FLOW_TOT_CUM | FURNACE1 GAS TOTAL FLOW | 19,425.23 | 19,406.36 | 19,425.27 | 19,415.82 | 6.12 | 01-08-2022 19:58:16 |
| F1_F1_ST2LOAD_EU | FURNACE1 STAND 2 LOAD % | 32.27 | 1.92 | 36.36 | 16.72 | 13.43 | 01-08-2022 19:58:16 |
| F1_F1_SOFT_ST2LOAD_HSP | MMSM STAND 2 LOAD | 65.00 | 65.00 | 65.00 | 65.00 | 0.00 | 01-08-2022 19:58:16 |

Hot on OnePlus
powered by Dual Camera

INNOVATIVE PROJECT-2

Benefits

| Parameters | Unit | Before Modification | After Modification |
|-------------------|----------|---------------------|--------------------|
| Blooms discharged | Nos. | 46 | 56 |
| Sp. Heat | Mcal/ton | 248 | 226 |

Savings: 2.11 Crores per year

INNOVATIVE PROJECT-3

Reducing idle running of Stelmor Blowers at Wire Rod Mill-2

Brief of Activity:

- In WRM-2 stelmor area 10 Blowers are present in each line to cool down the coil and achieve desired metallurgical properties.
- These blowers are controlled by a variable frequency drive
- The blowers motor data per strand is as follows:
 - 200 KW -2 no's
 - 315kW -8 No's
- **During the mill down time in case of breakdown or cobble ,it is observed that operator were not switching off the drives for a long time. this idle running is causing huge wastage of power**

INNOVATIVE PROJECT-3

INNOVATION

- The drives Start/Stop control is provided with PLC system
- A logic with interlocks is incorporated in the PLC such that when the upstream equipment (rolling Stands) is off for more than 10 min , the stelmor drives were commanded switched off .

INNOVATIVE PROJECT-3

BENEFITS

| Parameters | Unit | Before Modification | After Modification |
|--|---------------|---------------------|--------------------|
| Power Consumption (Running all blowers and considering 5min idle running per hour) | KW | 2920 | 2676 |
| Power Savings | KW | 244 | |
| Power Saving | MWH | 2137 | |
| Savings per year | Crores | 1.6 | |

Utilisation of renewable energy sources-Solar

Energy Utilization

- ❑ RINL has been exempted from complying RPPO.
- ❑ RINL commissioned 5 MW Solar Power Plant
Investment: Rs 36 cr
- ❑ RINL commissioned 0.5 MW Roof Top Solar Power Plant at three Building
Investment: RESCO Model



Utilization of Waste Material as fuel

| Name of the Fuel | Quantity of waste Fuel used (MT/ year) | GCV of fuel (kcal/kg) | Heat Value (million kcal/year) | Waste Fuel as % of total energy used |
|------------------|--|-----------------------|--------------------------------|--------------------------------------|
| Coke Dust | 32863 | 6860 | 225440 | 0.58 |
| LD Slag | 151734 | 1000 | 151734 | 0.46 |
| Met Waste | 414004 | 500 | 207002 | 0.63 |
| Tar sludge | 4205 | 7100 | 29856 | 0.09 |
| Benzol muck | 405 | 7100 | 2876 | 0.01 |
| ASP sludge | 224 | 7100 | 1590 | 0.00 |
| BF gas | 9868000 | 853 | 8417404 | 25.50 |
| LD gas | 487100 | 1837 | 894803 | 2.71 |
| Coke dust(sold) | 38044 | 775 | 29484 | 0.09 |
| Granulated Slag | 2426228 | 1070 | 2596064 | 7.86 |

Waste Fuel utilisation as % of total energy




GHG Inventorisation

As per ISO:14064:-

| Emission | Details |
|-------------|---|
| Scope 1&1.1 | Direct emissions from site chimneys determined from straight carbon balance |
| Scope 2 | Upstream emissions of electricity and steam from site. |
| Scope 3 | Other upstream emissions by-products from site |



| Scope 1 | Scope 1.1 | Scope2 | Scope 3 | Total CO2(t CO2/TCS) |
|-------------|-----------|----------|---------|----------------------|
| 1,01,76,522 | 41,43,192 | 5,85,361 | -43772 | 2.60 |



Involvement of employees, Team Work and Monitoring




- **Employee Involvement Through**
 - Quality Circles, Suggestion Schemes, Department Energy Teams, Participation in Energy Conservation Campaigns, Cost Control Campaigns, Water Saving Campaigns
- **Implementation Methods**
 - Low Cost/No Cost Ideas (Process Improvements, House Keeping Measures, etc) will be Implemented by Frontline officers
 - Medium Investment Projects through AMR Schemes
 - High Investment Schemes through Board Approval/COM
 - Special Task Forces for Implementing Important Energy Conservation Projects for Sinter Cooler, Steam Utilization and By product gases usage.

Monitoring Format

| DAILY ENERGY REPORT | | | | | | | | | |
|---------------------|----------------|---------------|----------------|----------------------------|-----------|------|---------|-------|--|
| Production | | | | | 09-Aug-22 | | | | |
| Month/Plan | ACTUAL On date | For the Month | Shm | PARAMETER | UNIT | NORM | ON DATE | QIM | |
| 5000 | 250 | 250 | COCCP | PROCESS CONC YIELD : | % | 79.0 | 71.8 | 71.9 | |
| Plan/day | 57 | 517 | But-1 | Mat.Coke Yld : | % | 68.2 | 65.3 | 65.3 | |
| | 58 | 519 | But-2 | C.O GAS YIELD : | KG/TM | 329 | 329 | 330 | |
| | 20 | 174 | But-3 | SP HEAT. CONS : | KCAL/TM | 423 | 654 | 631 | |
| | 52 | 472 | But-4 | C.O GAS CV : | KCAL/NUM | 4190 | 4228 | 4163 | |
| | 63 | 568 | But-5 | | | | | | |
| 400000 | 14060 | 141332 | SP | SP HEAT. CONS : | KCAL/TM | 21 | 31 | 21 | |
| | 8670 | 60891 | SP-1(M/C-1) | SP HEAT. CONS : | KCAL/TM | 28 | 18 | 18 | |
| | 5910 | 23111 | SP-1(M/C-2) | SP HEAT. CONS : | KCAL/TM | 28 | 50 | 47 | |
| | 0 | 57330 | SP-2 | SP HEAT. CONS : | KCAL/TM | 9 | 0 | 13 | |
| 250000 | 4925 | 43075 | BF-1 | SP HEAT. CONS : | KCAL/TM | 328 | 458 | 477 | |
| | 4875 | 43075 | BF-2 | SP HEAT. CONS-2 : | KCAL/TM | 338 | 538 | 590 | |
| | 0 | 0 | BF-3 | SP HEAT. CONS-3 : | KCAL/TM | 400 | 0 | 0 | |
| | 9800 | 86250 | BF(AID) | SP HEAT. CONS (AID) : | KCAL/TM | 493 | 502 | 538 | |
| | 0 | 0 | N.P.GAS(YIELD) | N.P.GAS YIELD : | KG/TM | 3007 | 3208 | 3260 | |
| | 0 | 0 | N.P.GAS(YIELD) | COKE RATE BF1 : | MT/TM | 323 | 485 | 477 | |
| | 0 | 0 | N.P.GAS(YIELD) | COKE RATE BF2 : | MT/TM | 425 | 481 | 484 | |
| | 0 | 0 | N.P.GAS(YIELD) | COKE RATE BF3 : | MT/TM | 450 | 0 | 0 | |
| | 1281 | 1235 | N.P.GAS(YIELD) | COKE RATE (AID) : | MT/TM | 453 | 483 | 481 | |
| | 1290 | 1259 | N.P.GAS(YIELD) | Pul.Gas BF-1 : | MT/TM | 50 | 76 | 78 | |
| | 1273 | 1210 | N.P.GAS(YIELD) | Pul.Gas BF-2 : | MT/TM | 100 | 76 | 73 | |
| | 0 | 0 | N.P.GAS(YIELD) | Pul.Gas BF-3 : | MT/TM | 110 | 0 | 0 | |
| | 1.0 | 1.0 | CO-BF1 | Pul.Gas (AID) : | MT/TM | 82 | 76 | 75 | |
| | 0.9 | 0.9 | CO-BF2 | N.P.GAS C.V. : | KCAL/NUM | 710 | 759 | 786 | |
| | 0.0 | 0.0 | CO-BF3 | COKE RATE : | MT/TM | 785 | 850 | 856 | |
| 89000 | 3360 | 36000 | SMS-1 | HOT METAL BATTERY : | MT/TM | 1000 | 995 | 995 | |
| 160000 | 3175 | 34054 | CS | SP HEAT. CONS : | KCAL/CS | 34 | 64 | 53 | |
| 500 | 24 | 27.4 | Heats | CONV.GAS YIELD : | KG/MTLS | 90 | 122 | 112 | |
| | | | | SP CONVEN CONS : | KG/MTLS | 57 | 45 | 48 | |
| | | | | SP FARGON CONS : | KG/MTLS | 226 | 187.8 | 182.1 | |
| | | | | SP LPG CONS : | MT/CS | 0.19 | 0.28 | 0.33 | |
| 160000 | 6160 | 49896 | SMS-2 | HOT METAL BATTERY : | MT/TM | 1013 | 998 | 998 | |
| 154161 | 5944 | 48148 | CS | SP HEAT. CONS(TOTAL) : | KG/MTLS | 62 | 33 | 36 | |
| 1032 | 40 | 36.0 | Heats | CONV.GAS YIELD : | KG/MTLS | 88 | 94 | 106 | |
| | | | | Total Heats : | MT | 54 | 64 | 63.4 | |
| 249000 | 977 | 8493 | BF-1 | LD Gas CV : | KCAL/NUM | 1760 | 1891 | 1830 | |
| 314161 | | | Heats | Liquid Steel Crude Steel : | MT | 8007 | 9520 | 85896 | |
| | | | | SP HEAT(IMP-2) : | MT/TM | 940 | 877 | 868 | |
| 100000 | 3507 | 28463 | BILLETS | SP HEAT. CONS : | KCAL/TM | 421 | 450 | 457 | |
| 46000 | 2311 | 19400 | BAR | SP HEAT. CONS : | KCAL/TM | 20 | 21 | 21 | |
| 0 | 0 | 0 | WRM-1 | SP HEAT. CONS : | KCAL/TM | 248 | 0 | 0 | |
| 60000 | 1720 | 15440 | WRM-2 | SP HEAT. CONS : | KCAL/TM | 263 | 249 | 258 | |
| 52000 | 1819 | 17599 | M.M.S.M | SP HEAT. CONS : | KCAL/TM | 400 | 373 | 418 | |
| 50000 | 2799 | 15010 | SBM | SP HEAT. CONS : | KCAL/TM | 300 | 288 | 347 | |
| 15000 | 1693 | 15347 | STM | SP HEAT. CONS : | KCAL/TM | 310 | 292 | 319 | |
| TPP | 116 | 119 | TPP | SP HEAT. CONS : | KCAL/TM | 749 | 836 | 805 | |
| PP-2 | 31 | 32 | PP-2 | SP HEAT. CONS : | KCAL/TM | 720 | 846 | 916 | |
| GETS | 2.6 | 2.5 | PP-2 | Heat Rate (pp-2) : | KWH/MT | 3071 | 3291 | 3112 | |
| TRT | 0.0 | 0.0 | | Heat Rate (pp-2) : | KWH/MT | 3.93 | 3.97 | 3.75 | |
| WHR | 14.4 | 16.1 | | POWER GEN.-BPTS : | MW | 23.9 | 11.8 | 13.6 | |
| Imp | 173.0 | 170.8 | | POWER GEN.-TRT + BE : | MW | 13.7 | 2.6 | 2.5 | |
| Plant Load | 334.8 | 337.8 | | POWER GEN.-AOD : | MW | 3.0 | 0.0 | 0.0 | |
| Steam (PP-1) | 18909 | 176308 | LOSSES | C.O.GAS BLEEDING : | % | 0.2 | 0.00 | 0.00 | |
| B Coal (PP-1) | 2761 | 29221 | | N.P.GAS BLEEDING : | % | 2.0 | 0.41 | 0.45 | |
| Steam (PP-2) | 2990 | 26138 | | OXYGEN BLEEDING : | % | 2.2 | 26.9 | 30.3 | |
| | | | | NITROGEN BLEEDING : | % | 13.9 | -0.6 | 1.9 | |
| VM (C Coal) | 26.12 | 25.79 | PLANT | SP POWER CONS : | KG/MTLS | 397 | 600 | 610 | |
| Ash (C Coal) | 10.98 | 11.19 | A.P.P | SP ENERGY CONS : | KG/MTLS | 2.80 | 6.92 | 6.92 | |
| VM (Coke) | 0.59 | 0.60 | TPP | OIL CONSUMPTION : | KL | 167 | 0 | 0.0 | |
| Ash (Coke) | 15.39 | 14.88 | | Oil and NG : | MT/MTCS | 298 | 454 | 454 | |
| Fuel Rate | 488.6 | COCC YLD | 241 | WHR-TRT | 70.22 | | | | |
| Power Cons | 486.77 | TRC YLD | 214 | WHR-TRT | 70.22 | | | | |
| SP Heat | 7.17 | LD G YLD | 263 | WHR-NBCCO | 31.56 | | | | |

PDF created with pdfFactory Pro trial version www.pdffactory.com

- Energy Savings are quantified with respect to displacement of Boiler Coal
- Electrical Savings are quantified by pegging with Electricity imported.
- Savings are certified by Energy Auditors



Energy Management System ISO:50001

Features:

- Significant Energy Use
- Developing Energy Management programmes.
- Operational control of identified energy aspects
- Monitoring and Measurement
- Risk & Opportunities
- Internal Audit
- Management Review
- Certified for ISO: 50001, Ver 2018 in July'21.**




Implementation of Corrective/Preventive actions

Bureau Veritas (India) Pvt. Ltd. RASHTRIYA ISPAT NIGAM LTD

To be completed by Bureau Veritas




| Date | Organization | Contract n° | Report n° | |
|---|---------------------------|--|---------------|--|
| 18-06-2022 | RASHTRIYA ISPAT NIGAM LTD | 12079424 | 50KS5VSS-IN01 | |
| Non Conformity Observed During | | 5th Surveillance audit | | |
| Process | | MMSM - Medium Merchant & Structural Mill | | |
| Standard | | ISO 50001:2018 | | |
| Clause | | 50k-8.1 Operational planning and control | | |
| Site Name | | HEAD OFFICE | | |
| Non Conformity Description | | | | |
| STANDARD REQUIREMENT: 8.1 Operational planning and control The organization shall plan, implement and control the processes, related to its SEUs (see 6.3), needed to meet requirements and to implement the actions determined in 6.2, by: | | | | |
| c) implementing control of the processes in accordance with the criteria, including operating and maintaining facilities, equipment, systems and energy-using processes in accordance with established criteria; | | | | |
| DESCRIPTION OF THE NON-CONFORMITY: The process of implementing the operational controls as per the defined criteria is not effective | | | | |
| OBJECTIVE EVIDENCE: Air fuel Ratio is maintained from 1:2.44 to 1:2.46 since Jan till May 22 as recorded in operatio daily logbook. However, same to be maintained at 1:2 to 1:2.2 ratio for mixed gas with calorific value of 2000 K Cal/Ncu and 1:5 to 1:6 in case of Coke oven gas with CV of 4000 to 4500 K Cal/Ncum as per Work instruction QSHE-I-Q-MSM-C E Issue date: 20 Jan 2021. | | | | |
| Grade | Lead Auditor | Auditor | | Organization Rep. |
| Minor | V S SATISH KUMAR | V S SATISH KUMAR | | Mr. Saibal Sen / Mr. A V S Satyanarayana |
| To be completed before | | | | |
| 31-07-2022 | VSS-IN | 1-1CM9LMJ | VSS-IN | 1-1CM9LMJ |
| To be completed by the organization | | | | |
| Root Cause Analysis (What failed in the system to allow this non conformity to occur ?) | | | | |
| Evidence of maintaining Air Fuel ratio as per procedure is not available as maintaining air fuel ratio depends upon calorific value of mixed gas. As per procedure, indicative ratio of 1:2.0-1:2.2 is given for mixed gas CV of 2000 Kcal/Ncum. Though procedure explicitly mentioned of adjusting air fuel ratio dynamically, the actual air fuel ratio with relation to CV is not defined due to misinterpretation | | | | |
| Correction (What is done to solve this problem) | | | | |
| The air fuel ratio is defined in the procedure based on CV of mixed gas, and procedure is amended. The copy of procedure is attached. Air fuel ratio up dated in data collection plan record which is also attached. | | | | |
| Corrective Action (What is done to prevent reoccurrence) | | | | |
| Awareness session conducted to all concerned on the revised procedure and data collection plan. | | | | |

- Plant has taken up Energy Objectives and Energy Management Action plans(795 Nos) to reduce energy consumption.
- DEPARTMENTAL ENERGY TEAMS** were constituted in various departments. The teams identified specific projects
- Departments conducted energy audits at various equipment through Departmental Energy Audit Teams



Environmental Projects & Projects linking with Carbon Emission Reduction

| Projects | Benefits |
|--|----------------------------|
| Revamping of Burden handling & Cast House FE system of Blast Furnace-1. | Reduce Dust emissions |
| Balacheruvu, Waste Water Treatment Plant - Commissioned in July 2014. | 253 Million Gallons |
| Commissioning of Appikonda Waste Water Treatment Plant | 220 Million Gallons |
| The Digital display board at Main Gate was inaugurated by CMD on 5th June 2014 for displaying the CAAQM and Stack analyzers. | Awareness |
| Dry Fog Dust Suppression System (DSS) in Expansion area of Raw Material Handling Plant, Sinter Plant & Blast Furnace. | Reduced fugitive emissions |
| Rain water harvesting scheme near 18 MLD plant | Ground water recharging |



Energy Conservation Projects identified for next three years

| SI No | Name of Energy Conservation Activity | Year | Impact (Mcal/tCS) |
|----------------------|---|---------|-------------------|
| 1 | Recommissioining of LD Gas holder-2 | 2022-23 | 14.9 |
| 2 | To improve Pulverized coal injection at BF-1 from 107.2 Kg/tHM to 121 kg/tHM at Blast Furnace | 2022-23 | 8.7 |
| 3 | To improve Pulverized coal injection at BF-2 from 100.3 Kg/tHM to 121 Kg/tHM at Blast Furnace | 2022-23 | 12.9 |
| 4 | To improve power generation at SHRPP from 1.69 MW to 5 MW. | 2022-23 | 13.2 |
| Total Savings | | | 49.8 |

Environmental Projects & Projects linking with Carbon Emission Reduction

| Name of Projects | Registration Number | Expected CERS |
|---|---------------------|---------------|
| BF3 Top Pressure Recovery Project | 9613 | 60410 |
| COB-4 Turbine at Battery-4 | 9988 | 68540 |
| Waste Heat Recovery from Stoves of BF-3 | 10024 | 44932 |

- ❑ 4 No. of projects registered (TRT, COB4, BF3-WHR).
- ❑ UNFCCC issued 1,71,929 CERs to RINL for three CDM projects.

Adoption of Green Technologies

| Name of Technology | Features | Energy Savings(TOE) | GHG redn(tCo2) |
|---|--------------------------------|---------------------|----------------|
| <u>Coke Dry Quenching Plant</u> | Power gen: 2X7.5MW | 115285 | 689586 |
| <u>Top Pressure Recovery Turbine</u> | Power gen; 2x12 MW | 21257 | 127152 |
| <u>LD Gas Recovery System</u> | 80000 Cum | 58022 | 347060 |
| <u>Evaporative Cooling System</u> | 13 ata steam: 19 t/hr | 12173 | 72814 |
| Preheating of combustion air at CRMP | Air preheating: 250degc | 3469 | 21062 |
| Gas and air recuperators in ROLLING MILLS | Air : 450 degC Gas:250 degC | 16105 | 57088 |
| Reducing GHG emission by about 13 lakh tons annually | | | |

Adoption of Energy Efficient Technologies-Unique Features of RINL

| Name of Technology | | Level of Diffusion |
|--|------------------------------|--------------------|
| <u>Coke Dry Quenching Plant</u> | First Time in India(1990) | 13.5% |
| <u>Top Pressure Recovery Turbine</u> | First Time In India(1993) | 13.9% |
| <u>LD Gas Recovery System</u> | First Time in India(1991-93) | 50% |
| <u>Evaporative Cooling System</u> | First Time in India(1993) | 25% |
| Sinter Cooler Waste Heat Recovery(Power Gen) | First Time in India(2014) | 5% |


Action Plan to Achieve “NET ZERO-2070”

| Parameters | 2021-22 | 2030 | 2030 (with policy intervention) | 2047 | 2047 (with policy intervention) |
|--------------------------|-------------|-------------|---------------------------------------|-------------|---------------------------------------|
| GHG Emissions | 2.60 | 2.40 | 2.10 | 2.30 | 2.00 |

Action plan (With policy intervention)

- Usage of Natural Gas based on availability and cost
- Usage of more scrap based on availability of quality Steel Scrap
- Installation floating Solar Power Plant reservoirs (KBR) with financial assistance from National Clean Energy (NCEF)
- Installation of WHR systems like regenerative burners in reheating furnaces and Coal Moisture Control with financial assistance from National Clean Energy (NCEF)
- Usage of hydrogen in Blast furnace based on availability and cost

Roadmap for reduction of Energy Consumption & GHG emissions.



Action plan to achieve 2.40 tCO2e/tCS by 2030,

- Increasing Pulverized Coal Injection in Blast Furnace up to 150 Kg/tHM
- Optimizing power generation from Waste Heat Recovery system like CDQ, SHRPP & TRT
- Process optimization (combustion improvement, installation of VFD drives, optimizing fuel rate in BF)

De-carbonising Options for Iron & Steel



| Parameters | Unit | Present | | Target | Impact (tCO2/tCS) |
|---------------------------|----------|---------------------|------|--------|-------------------|
| GHG emissions | tCO2/tCS | 2.60 | | 2.10 | 0.50 |
| Waste Heat Recovery | MW | BPTS , COB4,COB5 | 28 | 33 | 0.04 |
| | | GETS | 5 | 10 | |
| | | SHRPP | 1.85 | 8 | |
| | | TRT | 6.28 | 10 | |
| Usage of Scrap at SMS | Kg/tCS | 80 | | 200 | 0.240 |
| PCI Rate | Kg/tHM | 94 | | 150 | 0.034 |
| Natural Gas(If Available) | Cum/tHM | 0 | | 120 | 0.07 |
| Power Optimization | Kwh/tCS | 402 | | 350 | 0.04 |
| Heat Optimization | Mcal/tCS | 1834 | | 1700 | 0.07 |
| Yields Improvement (Coke) | % | 72.5 | | 74.5 | 0.06 |

Net Zero Ideas For Steel Industry



- ❑ Usage of Hydrogen in place of PCI coal
- ❑ Injection CO Gas in BF, Syngas injection into BF
- ❑ Carbon Capture usage and Storage (CCU&S) technology

Awards

- **CII National Award for Excellence in Energy Management & National Energy Leader Award-2021**
- **CII National Award for Excellence in Energy Management & National Energy Leader Award-2020**
- **National Energy Conservation Award-1st Prize from Ministry of Power-2019**
- **CII National Award for Excellence in Energy Management & National Energy Leader Award-2019**
- **CII National Award for Excellence in Energy Management-2018**
- **CII National Award for Excellence in Energy Management-2017**

Thank you



राष्ट्रीय इस्पात निगम लिमिटेड
RASHTRIYA ISPAT NIGAM LIMITED

K Sudhakar, Email: konthamsudha@vizagsteel.com, Mob: 9989307213
S Kumar, Email: sudhanshu_k@vizagsteel.com, Mob: 9959785844

