


Unit Vikram Cement Works Thermal Power Plant (2x23 MW) Welcome You!



23rd
National Award for 2022
Excellence in Energy Management


Team Presenter

Praveen Vijayvargiya – GM,TPP
Rakesh Sharma- Sr. Manger, TPP
Angad Singh – Manager TPP

Company- UltraTech Cement Ltd



3rd Largest producer cement in the world (Excluding-China)
Largest manufacturer of grey cement in India



Consolidated Capacity 119.95 Million Tonnes Per Annum (MTPA) of Grey Cement




VISION
TO BE THE LEADER IN BUILDING SOLUTIONS

MISSION
To deliver superior value to stakeholders on the four pillars of **SUSTAINABILITY, CUSTOMER CENTRICITY, INNOVATION AND TEAM EMPOWERMENT**

UltraTech Cement Ltd – Vikram Cement Works

- UTCL : A part of ABG the **best employer in India and Asia Pacific region.**
- Unit has **46 MW** Captive Thermal Power Plant (2X23MW).
- Installed Capacity **8.9MWp** Solar Power Plant
- Installed **482KWp** Roof Top Solar Plates
- First Cement Plant in India that
 - 1) Acknowledged as pioneer of TPM, JIPM Japan in 1995
 - 2) Obtained ISO 14001 in 1997, EMS Certification from DNV
- Certified with ISO 9001, 14001, OHSAS 18001, ISO 50000, ISO 27001, SA8000
- **Certified with ISO50001** & Implemented Energy Policy in 2013
- Adopted WCM Excellence Model & Achieved **Two times Gold award**
- Unit awarded with **CII National Excellent Energy Efficiency Award in power**
 - 1) Sept,2019 as CII National Excellent Energy Efficient Award
 - 2) Sept,2021 as CII National awards as “Energy Efficient Unit”





TPP Overall process diagram & Major equipment



Steam Turbine, capacity 2x23 MW
Make: Hangzhou Steam Turbine Co.Ltd
Type: Single Cylinder Multi stage, three uncontrolled extraction condensing type
Speed: 7026RPM,
Inlet steam Parameter: 90 Kg/cm ² , 535 Deg.C
Air Cooled Condenser (6 Fans)
Make: Shanghai Turbine Co.Ltd
Air Cooled Dry type with Force draft fans
VFD control force draft fan.
FRP Blade with Dia 9.7m, aerodynamic design
Generator, Capacity (2x23MW)
Make: Shandong Jinan Power Equipment Factory
Rated Voltage: 11KV
Speed: 3000RPM, HZ;50
Boiler, Rated Capacity (2x130TPH)
Make: Dongfeng Boiler Industry Group Co. Ltd.
Type: CFBC with Multi fuel firing ability, Hot Cyclone
Inlet steam Parameter: 100 kg/cm ² , 535 + 50C

Energy Performance (Sp. Energy Consumption)

Parameters	YTD Figure			Remarks for Deviation
	FY-21	FY-22	Gain/loss	
Auxiliary (%)	7.10	7.06	1.18 %	Gain 1.18% Many Encon Project taken
Gross Heat Rate (Kcal/Kwh)	3010.59	3016.56	5.97 Kcal/kWh	Plant Start/Stop Increased in FY-22
Plant Load Factor (%)	68.10	68.55	0.45 %	TPP Run As per load demand
Availability (%)	99.6	100	0.4 %	Plant Availability 100%



Major Energy Conservation Projects (FY2019-22)

“INNOVATION = IDEA + LEADER + TEAM + PLAN”

Power cost Rs./KWH	5.13
Fuel cost Rs./KWH	4.05
Aux (%)	8.26
PLF (%)	66.98

2019-20

EnCon Projects	16 Nos.
----------------	---------

Energy Saving
28.9 Lac Units

Cost Saving
Rs. 148.3Lac

Power cost Rs./KWH	4.57
Fuel cost Rs./KWH	3.55
Aux (%)	7.10 %
PLF (%)	68.11%

2020-21

EnCon Projects	23 Nos.
----------------	---------

Energy Saving
25.2 Lac Units

Cost Saving
Rs. 140.2Lac

Power cost Rs./KWH	6.79
Fuel cost Rs./KWH	5.75
Aux (%)	7.06 %
PLF (%)	68.55%

2021-22

Major EnCon Projects Identified	32 Nos.
---------------------------------	---------

Energy Saving
6.8 Lac Units


Cost Saving
Rs. 142.8Lac

Thermal Saving :897.6 Mkkal/MTOE
Electrical Saving: 60.9 Kwh/MTOE
Total Saving Rs. 431.2 Lacs

Our Vision
FY2022-23
APC-5.5 %
PHR-2950 Kcal/kWh

ROI 1.45 Years

Year	No of EnCon projects	Investment Returnable Capex	Electrical Saving	Electrical Saving	Thermal Saving	Saving	Total Saving
UOM	Nos.	(INR Million)	Million Kwh	Million kWh/MTOE	Million Kcal/MTOE	INR Million	INR Million
FY2019-20	16	50.53	2.89	14.83	0	0	14.82
FY2020-21	23	12.26	2.5	11.42	219.56	2.6	14.02
FY2021-22	32	0.31	0.68	58.46	678.05	9.67	14.28



Energy Mapping data
FY2021-22

PLF: 68.55%
Aux: 7.06%


Area for Improvement:

- Boiler fans
- Transformer losses
- Air Cooled Condenser
- Aux. Cooling Water / Cooling Tower
- Compressor Power

Auxiliary Power (%) YTD FY-2021-22



Plant Heat Rate Kcal/KWH YTD FY-2021-22




ANALYSIS OF CAPTIVE POWER PLANTS




S.No	Area/Equipment	CFBC(kW/MW)	AFBC(kW/MW)	VCW (KW/MW)
1	Boiler Feed Pump (BFP)	22.60	20.00	20.43
2	Secondary Air (SA) Fan/Forced Draft fan(AFBC)	6.07	10.50	4.34
3	Compressors	4.26	4.00	4.26
4	ACC fans	3.05	2.90	7.85
5	Induced draft (ID) Fan	10.50	2.50	14.31
6	Primary Air (PA) Fan	10.20	2.00	12.37
7	Water Treatment Plant (WTP)	0.74	0.70	0.78
8	Coal Handling Plant (CHP)	0.61	0.70	0.64
9	Auxiliary Cooling Water Pump (ACWP)	1.56	3.10	1.42
10	Condensate Extraction Pump (CEP)	1.59	1.50	0.98
11	ESP	1.55	1.20	1.32
12	Lighting	0.58	0.50	0.58
13	AC & Vent	0.58	0.50	0.62
14	Boiler Aux.	1.51	3.50	0.68
15	Over all Auxiliary Consumption (%)	6.53	5.36	7.06%

Data source from CII

Road map for achieving benchmark



- fly ash generated from boilers are conveyed to fly ash silos.
- From Silos, fly ash is again transported through Bulker to cement mill silos where it is consumed 100% for cement manufacturing.
- It is used completely as a raw material for cement plant. It is added in the raw meal additive hopper for further processing at cement plant.



Fly Ash Transportation by Bulkers



S.No.	Particulars	UOM	2019-2020	2020-2021	2021-2022
1	Ash Stock in Plant (yard + pond)	Tons	0	0	0
2	Ash Generated	Tons	11272	20967	40954
3	Ash Utilization	%	100	100	100
4	Ash Utilized in Fly Ash Bricks	%	0	0	0
5	Ash Utilized in Mine filling	%	0	0	0
6	Ash Utilized for Roads pavements	%	0	0	0
7	Ash Utilization in Other Areas – Please mention below	%	NA	NA	NA
8	Expenditure on Ash Utilization (annual)	NR (Lakhs)	18	18	19.5

Ash Handled (Wet Method)	%	NA
Ash Handled (Dry Method)	%	100
Ash Handled (semi wet)	%	NA



100 % of Fly Ash transport to Cement Plant for Cement Production.

S.No.	Particulars	UOM	2019-20	2020-21	2021-22	Remarks
1	Total CO2 Emissions Per kW of Generation	Ton/kWh	0.00086	0.00108	0.00092	
2	Current SOx Emissions at Full Load	mg/Nm3	375.2	295.2	375	
3	Current NOx Emissions at Full Load	mg/Nm3	137.2	126.4	182	
4	Particulate Matter	mg/Nm3	29.4	29.8	32	
5	Mercury	mg/Nm3	<0.001	<0.001	<0.001	

Detailed plan for achieving the current emission norms for thermal power plants.

- Raw Meal Powder/Limestone screen reject used and maintaining environment norms.
- Less Sulphur coal fired in Boilers.
- Auto SMS alert to Concerned Persons while the Environment parameters is exceeding alarming limit before reaching the CPCB Norm.

CPCB ENVIRONMENT MONETERING SYSTEM



☐ DM water Consumption of Plant (Unit - %)

FY	2019-20	2020-21	2021-22
%	2.46	1.45	1.43

☐ Raw Water Consumption of Plant (Unit – M³/MW)

FY	2019-20	2020-21	2021-22
M ³ /MW	0.293	0.196	0.191

☐ Weather Plant is Zero Liquid Discharge- Yes

- RO Reject water being used after treated in Gardening in Thermal & Cement Plant.
- RO reject water & Continues Blow Down water is used in Cooling Tower Make Up.



Optimization of Power Consumption by elimination of Air blower for Neutralization of WTP Effluent Water

- Reduction of auxiliary power consumption approx.-
- 15 KWH*2 Hrs.*13 days/month*12= 4680 KWH/year
- Cost saving- 4680*Rs 8.5= Rs 39780 per year**
- Maintenance free, safe and easy to work arrangement



Installed Diaphragm drum manual operating pump

- Eliminate the risk of contacting with chemical hazards
- Power cost saving- 109.5X5.5= Rs 602/year



IMPROVEMENT PROJECT ON FOREBAY MESH REPLACEMENT

- Total power saving-43058 kwh/ Annum
- Power cost saving- Rs 3.66 Lacs/annum




List of Major EnCon project planned in FY 2021-22

Sl. No.	Improvement Project	kWh/Day	Running Days	Kwh/Year	Saving In Millions kWh	(Rs. in Lac/Annum)	Saving in Rs. Millions
1	ACW Power Optimization by Reducing Discharge Pressure from 1.48Kg/cm ² to 1.35kg/Cm ² & Replacement of pump with High energy efficient pump designed to deliver 600m ³ /hr. flow at 2kg/cm ²	200	365	73000	0.073	495670.00	0.50
2	BFP#3 SP power consumption running high up to 2.15%, system check and found its ARC valve having passing. Ask the vendor regarding passing. He came & during inspection it is found that stem and valve seat found damage. It is replaced under warranty on FOC Basis. After replacing SP consume. reduced up to 1.81% and Saving is approx. 30 Kw*24h=720 Kwh/day.- Saving in APC is 0.09%. Saving in cost@₹ 7.63= 20 lac / Annum. We also saved the cost of new ARC@ 5-6 lac. It is done in FOC by little bit efforts.	720	365	262800	0.263	1784412.00	1.78
3	CHP Bucket Elevator 1 & 2 Operation with Single VFD based one selection	25	150	3750	0.004	25462.50	0.03
4	Cooling Fan Installation in GT-1 Radiator cooling to reduce losses	5	365	1825	0.002	12391.75	0.01
5	LED Installation in place of HPSV at DG and CHP Area	9	365	3285	0.003	22305.15	0.02
6	Boiler Drum level control on cascade DP mode operation	21	365	7665	0.008	52045.35	0.05
7	Bed Ash cooler 1A & 1B Auto Start/Stop along with close loop operation	15	365	5475	0.005	37175.25	0.04
8	BFP-3 suction filter cleaning improvement job without taken shutdown (6 nos. shutdown avoided for 4Hrs.)	12	365	4380	0.004	29740.20	0.03
9	Air loss trap installation in place of Electronic drain at air receivers	72	365	26280	0.026	178441.20	0.18
10	Diaphragm drum type pump without power consumption	15	365	5475	0.005	37175.25	0.04
11	Boiler Fan power reduction through PID fine tune as per type of coal used for feeding	352	365	128480	0.128	872379.20	0.87
12	VAM & AC Power reduction initiatives by reducing Minimum RPM locking and set point reduction & VAM & AC Power reduction initiatives by reducing Minimum RPM locking and set point reduction.	6	365	2190	0.002	14870.10	0.01
13	MOT mist fans vent line of both TGs modified. In old system both vent goes to down tank at ground floor and than vented in air. Due to this fan takes more power to discharge vapours in air and also oil waste in air in vapour form.	50	365	18250	0.018	123917.50	0.12
14	Boiler fan Power reduction by Process optimization.	157	365	57305	0.057	389100.95	0.39
15	Compressor power optimization through process optimization	128	365	46720	0.047	317228.80	0.32
16	PA and SA fan Bell mouth suction duct 08 Nos. wire mesh size increased upto 4 sq. Inch from 1 sq. inch. power saving approx. 100 Kwh /day. Saving in APC is 0.01%. Saving in cost@₹ 7.63= 2.80 lac / Annum.	100	365	36500	0.037	247835.00	0.25
Heat Rate			Kcal (Million)		Coal (MT)		Rs. (8000)
17	Turbine Heat rate improvement by increasing the turbine inlet steam temp by 3 Deg .C	1692.432		0.30		2.40	
18	HP Heater drain bypass valve leakage rectification increased temp up to 5.3Deg.C	5093.61588		0.90		7.21	

Specific CO₂ Emission of TPP (MT CO₂/MW)

1. Use low Sulphur Fuel (With blending of Different Coal).
2. Use Raw Mill Power & Crushed Lime Stone for Sulphur capturing.



Green Power

- ❑ 8.9 MWp Solar power installation done and power generate Avg. 45 to 50 MW/day.
- ❑ 482KWp Roof top solar plats installed at Druga colony and staff colony school buildings.
- ❑ Study have been done for 13 MW WHRS.
- ❑ 1.5MWp Expansion is going on at Loader colony area
- ❑ Feasibility study is planed for roof top solar plats at thermal power plant



100% Green House Building :
VCW Hospital, ABPS School , ABHSS- School , e3 Cinema Hall, Shopping Complex, and young manager home buildings




8.9 MWp Solar power Generating 45 to 50 MW/day power



482 KWp Roof top Solar plats power Generating Power 1.5 to 2.35 MW/day



System Architecture




Benefits :

1. Reduction in Unplanned Failures by 10%
2. Maintenance costs reduced by 5%.
3. Improvement in Overall Heat Rate by around 10 Kcal/kWh
4. Improvement in decision making through system supported advisories and discipline to maintain operating parameters consistently (irrespective of individual operator's decisions)
5. Help operating team to act proactively on change in pattern of critical parameters of equipment (through triggering of alarms)

Advanced Artificial Intelligence solution for Improved Boiler Reliability and Performance


Reliability Initiative

Before: Stand alone OFC network for EMS and LMS




Digitization

EMS system Hook up with DCS Plant automation System



After: Redundant OFC network for EMS and LMS



Environment Initiative

Fugitive dust control during fly ash bulker loading

Before

Fork type level sensor



After

Vibrating rod type sensor



Safety Initiative

Pull rope type switch installed in all take-up pulley

Before



After



MEA Report findings



MPR Meeting


REPORT		Today			MTD	
Area	Parameter	Line # 01	Line # 02	Combined	Total	Avg
	Generation (KWH)	318000	4E+05	684000	1352000	19176000
	Auxiliary (KWH)	24400	28400	52800	104000	1515811
	Auxiliary (%)	7.67	7.76	7.72	7.69	7.91
	Auxiliary from cement plant					
	Auxiliary % (cement plant)					
	Total Steam Generation (MT)	1336	1535	2871	2871	115333
	Specific Steam Consumption(Kg/kwh)	4.20	4.19	4.20	4.21	4.19
	Shut Down power	0	0	0	0	0
	Plant Load Factor (%)	57.61	66.30	61.96	61.23	58.8800
	Avg.Load (MW)	23	13.25	15.25	28.50	28.17
	Gross Heat Rate (Kcal/Kwh)	3017.67	3014.80	3014.80	3016.78	3014.38
	Ambient Air Temperature (avg/max/min)	27.94/34.26/24.58				
	Power Cost (Rs./KWH)	4.60	4.63			
	Fuel Cost (Rs./KWH)			3.73	3.75	
	Lime Stone Cost (Rs./KWH)	0.040	0.040	0.040	0.040	
	Fix cost (Rs./KWH)					
	Electricity Duty (Rs./KWH)				0.75	
	RPM (Assumption as per flash)				0.099	
	Stores & Spares (Rs./KWH)				0.052	
	Fly ash Credit @814 Rs/MT (Rs/kwh)	0.080	0.085	0.081		
	Boiler Efficiency (%)	87.52	87.52	87.52	87.36	87.41
	Fuel Consumption (Kg/KWH)	0.421	0.452	0.451	0.452	0.423
	Coal Consumption (MT)	154.42	154.42	308.84	610.86	8028.69
	Coal GCY (Kcal/KG)	6677	6677	6677	6677.00	7107.66
	O2 Average (%)	2.5%-3.5%	4.60	4.74		
	coal feeder status	OK / Not OK	OK	OK		
	Bed ash coolers status	OK / Not OK	OK	OK		
	Vind Box pressure (mmwc)	390	390			
	LOI FAIBA (%)	<2.5	7.24	6.94		
	BLAINE FLY ASH(sqmr/kg)					
	Lime Stone Consumption	20.12	25.43	45.55		
	Fly Ash Generation	31.18	38.23	69.41		
	Soot Blower status	OK / Not OK	OK	OK		
	Total Coal Feed (MT)	394.7				
	CHP Run Hrs	11.12				
	CHP Average Feed rate (TPH)	48.51				
		mm 8	1.52			

KPI's review meeting


TPP Daily Report													
19-Sep-19													
		Budget			Today			MTD			YTD		
Parameters	Units	Unit-1	Unit-2	Total	Unit-1	Unit-2	Total	Unit-1	Unit-2	Total	Unit-1	Unit-2	Total
Plant Performance													
Availability Factor	%	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	46.4	99.4	72.9
OTG Running Hours	Hrs	744.00	744.00	1488.00	24.0	24.0	48.0	72.00	72.00	144.000	1785.5	3780.0	5498.5
Plant Load Factor	%	49.04	78.70	63.87	54.71	62.30	58.51	56.64	64.00	60.33	56.29	79.44	67.85
Gross Generation	KWh	8392000.00	13468000.00	21860000.00	302000	344000	646000	938000	1060000	1998000.00	22560000	67966000	94472000
Aux Consumption	KWh	695000.00	1077000.00	1772000.00	23800	27000	50800	72500	82300	154800.00	1820716	5805610	7626528
Aux Power from Cement Plant	Kwh	0.00	0.00	0.00	0	0	0	0	0	0.0000	0	0	0
Aux power including SD	Kwh	8.37	8.07	8.18	7.88	7.85	7.86	7.79	7.76	7.77	8.29	8.54	8.48
Net Generation	MWh	7697000.00	12391000.00	20071000.00	278200	317000	595200	865900	977000	1843200.00	20639999	62160390	82806987
Average Load	MW	11.28	18.10	14.69	12.58	14.30	16.92	13.03	14.70	17.75	12.95	18.27	13.22
TO (L/Steam)	MT	0.00	0.00	0.00	1260	1442	2700	3949	4451	8400.00	94083	284450	375333
Steam from Boiler-1	MT	0.00	0.00	0.00	1260	0	1260	3949	0	3949.00	98077	0	98077
Steam from Boiler-2	MT	0.00	0.00	0.00	0	1442	1442	0	4451	4451.0000	1006	284450	284450
Sp. Steam Cons	Kg/Kwh	0.00	0.00	0.00	4.20	4.19	4.20	4.21	4.20	4.20	4.18	4.14	4.15
Turbine Heat Rate	Kcal/KWH	0.00	0.00	0.00	2641	2650	2659	2656.78	2656.86	2656.81	2653	2620	2625.45

Daily Energy Rev. Meeting



DAILY AUXILIARY POWER REPORT														
Report Date: 2019-09-03														
Sr. No.	System description	Equipment Name	Phase Load (KV)	2019-09-03			2019-09-02			2019-09-01				
				Average Today	Sum of Aux.	SEC	% Aux.	Y. Day	Sum of Aux.	SEC	Y. Day	Sum of Aux.	SEC	
														Today
1	Boiler System	IDFAN-1	120	98	1912					2019		2012		
2		PA.FAN-1	450	282	6593				6542		6421			
3		SA.FAN-1(LT.MOTOR)	250	21	410	3667	1.62	19.03	501	3758	1.41	428	970	1.39
4		P.FAN-1	185	0	0				0		0			
5		Boiler-1 Auxiliaries	338	36	632				637		708			
6		IDFAN-2	120	87	2244				2823		2365			
7		PA.FAN-2	1000	312	7357				7881		7541			
8		SA.FAN-2(LT.MOTOR)	250	39	604	10769	1.34	21.20	717	11688	1.54	671	1123	1.28
9		P.FAN-2	185	0	0				567		532			
10		Boiler-2 Auxiliaries	336	35	564				567		532			
11		BFP-1	1000	0	0				0		0			
12		BFP-2	900	585	13677	13677	2.12	26.32	14323	14323	2.09	14106	14106	2.11
13		BFP-3	900	0	0				0		0			
14	Compressed Air System	Service Comp-1	275	0	0				0		0			
15		Service Comp-2	275	0	0				0		0			
16		Service Comp-3	275	0	0				0		0			
17		Inst. Air Comp-1	100	76	2158	2610	0.40	5.14	1667	2311	0.34	1860	2210	0.33
18		Inst. Air Comp-2	100	42	167				159		59			
19		Inst. Air Comp-3	100	49	22				38		14			
20	Ash handling and Compressor system	86	25	262				247		239				
21	Turbine System	TG-1 Auxiliaries	578	36	302				296		299			
22		TG-1 ACC	6 X 110	71	1907	2198	0.71	4.21	1438	2292	0.72	1997	2241	0.70
23		TG-1 CEP	2 X 90	22	529				558		545			
24		TG-2 Auxiliaries	606	63	823				814		808			
25		TG-2 ACC	6 X 110	55	1060	2443	0.71	4.81	1189	2597	0.71	1092	2477	0.71
26		TG-2 CEP	2 X 90	24	562				555		577			
27		ACV-1	132	0	0				0		0			
28		ACV-2	132	60	1417	1648	0.26	3.24	1412	1536	0.23	1336	1501	0.22





Ideation Drive at Unit Level




Hackathon- TPP Contribution



- Kaizen & Suggestions Schemes
- Annual Improvement Projects
- Organization Knowledge
- KIP Visits
- External & Internal Trainings on Energy
- Participation in Seminars
- Team competition
- Energy Conservation Week
- Awareness creating to all Colony residents for Energy Conservation
- Online Training need identification through Poornata on Energy Conservation
- Reward & Recognition





Control Valve Dismantling, Gasket Replacement, stem, seat, cage, aping, blue matching & calibration

Energy Management System Standard




*Miles to go ...
Sky is the limit*



1.0 Reduction in Fuel Cost

Theme	Reduction in Fuel cost by use low-cost Fuel ,blending with high GCV Coal.
Problem	Present Fuel cost is increasing continuously and had reached up to 1400 Rs/MCV. This high Fuel cost is resulting in increase of TPP Generation cost.
Solution	<ul style="list-style-type: none"> • Carbon shale was introduced in ratio of 10 % by heat in Boiler and trial was taken . Trial was successful and we had now reached to 20% fuel mix.
Benefit	<ul style="list-style-type: none"> • Saving in Fuel cost by 160 Rs/MCV for 20% of Carbon shale used with Imported coal and reduce Power Generation Cost. • Increase Fly ash Generation due to use of High ash coal. • Total saving in terms of Imported Aus. coal (March to June'21) - 113.28 Lacs



Coal Shale

Theme

Air loss trap installation in place of Electronic drain at air receivers

Problem

It was observed that there was loss of compressed air every time when electronic drain operates; it was not much reliable as we must manually set timer & it is not operated on water level / moisture content basis.

Solution

Electronic drain by air loss trap drain, which can help to discharge Moisture only & trap compressed air by balancing .There is no loss of compressed air hence optimizing compressor power .

It also increase system reliability as Discharges condensate as soon as it is formed.

Following features are also available in air loss trap system

- ✓ Leak proof operation
 - ✓ Can be repaired online after proper separation
 - ✓ Robust & Reliable
-
- ✓ Discharges condensate as soon as it is formed
 - ✓ Can handle large quantities of condensate.
 - ✓ Avoids corrosion of compressed air lines and consumers.
 - ✓ Power Optimisation by **355 kwh/day, saved Rs. 11.01 Lacs/ annum**
 - ✓ Reduced manpower intervention , increasing safety
 - ✓ S&S cost reduction upto Rs 0.20 lakh per auto drain

Benefit

Before



Electronic drain

After



Air loss trap

Theme

Boiler Fan power optimization by Process parameter optimization along with Advance process optimizer (Digitalization)

Problem


Higher Specific fan power consumption for Boilers-1&2 .

Solution

- Optimization of Bed height 8.5 Mpa to 7.8 Mpa.
- Maintain Optimum Bed temp. (925 °C To 938 °C) according to power demand of Cement Plant.
- Maintain Sufficient Oxygen level in Boiler 4.0% to 3.5 %.
- Both Boiler and Plant running on Island Mode.
- APC optimizer maintained constant Pressure (90 Kg/Cm2) and Temp (540 °C .) of Main Steam along with all above parameters in cascade operation.

Benefit

- ✓ Boiler-1&2 Fan power reduced by **980 Kwh/day** (i.e. optimized **sp.Power 1.10 kwh/MW of generation, in Rs. 27.48 lacs/ annum**).
- ✓ Eliminated manual intervention



Theme

Problem

Solution



Benefit

Boiler Drum level control on cascade DP mode operation

- High Specific Energy Consumption of BFP due to pressure fluctuation.
- BFP operates in Auto in drum level, hence BFP discharge pressure fluctuating
- High pressure drop across control valve due to maintaining high discharge pressure set point

- DP logic developed on cascade operation considering power generation, Boiler steam flow, Steam temperature & Boiler drum. BFP Minimum RPM Locking reduced from 87% to 83%
- BFP Standby pump avoid started by changing Header pressure set point 103 kg/cm² to 97.5 kg/cm²


- ✓ **Eliminated manual intervention & pressure fluctuations**
- ✓ **Energy Saving: 482 kwh/day, 159060 kwh /Annum**
- ✓ **Annual Saving in terms of money: 13.52 Rs. Lac**



Sl. No.	Improvement Project	kWh/Annum	Saving In Millions kWh	(Rs. in Lac/ Annum)	Saving in Rs. Millions
1	ACC Fan Interconnection to optimization of ACC Pas Power in Summer season	135050	0.135	1147925	1.15
2	Energy Efficient Condensate Extraction Pump installation.	5475	0.005	46537.50	0.05
3	APH Tube Bundle Replace in Boiler-1	547500	0.548	4653750.	4.65
4	Attemperator tapping form BFP discharge for power saving	21900	0.022	186150.	0.19
5	LT motor 09 nos. with energy efficient motor	9125	0.009	77562.50	0.08
6	Boiler feed pump replacement for single unit operation	73000	0.073	620500	0.62
7	Installation of 482 KWp Roof Top solar in Colony areas	70000	0.070	595000	0.60
8	Solar 1.5 MWp installation under PPA	2190000	2.190	18615000	18.62
9	8.92 MWp Solar installation under PPA	18250000	18.250	155125000	155.13
Heat Rate		Kcal/kWh	Kcal	Coal (MT)	Rs. In Million
1	ACC Fan Interconnection for improve TG Heat rate by improve vacuum set point from -0.80 to -0.83 Kg/CM2	24.76	4373606400	774.09	6.193
2	Feed water drain and steam line drain valves replace with new one.	0.5	88320000	15.63	0.125
3	APH Tube Bundle Replace in Boiler-1	6.85	1209984000	214.16	1.713



Accredited 8 Nos of Awards from CII



UltraTech Cement Limited, Unit-Vikarm Cement Work received 160 Nos. award and certification in different Categories from 1990 to till date...

Learning :

- Replication of various ideas and proven technology .
- Implementation of best practices learned from CII or other award function.
- Improving knowledge of the process and new technology.
- Avail opportunity to achieve high business benefits.
- Learned Project planning ,Execution and Application engineering.
- Enhanced uses of various QC tools, Analysis & presentation skill.

Sharing:

The Success Story of same shared among our group units of

ABG & Idea Sharing Platform “ I Love My UltraTech”

“Alone we can think so little; together we can think a lot”

Best Practice: Suggestion shared at I Love My UltraTech

- Suggestion-1**
VAM system at Cement plant
Name: Navien Dave
Unit: Vikram Cement Works
Idea: VAM System in Cement plant with 100% Heat Utilization.
- Suggestion-2**
Energy Reduction in BFP
Name: Prasad Sati
Unit: Vikram Cement works
Idea: Auxiliary power reduction in boiler feed pump
- Suggestion-3**
Touch less Lift operation
Name: Anurag Garg
Unit: Vikram Cement works
Idea: Touch less lift/elevator operation
Email id: anurag.garg@adityabirla.com
- Suggestion-4**
Treatment Cooling Tower without chemical
Name: Manoj Gupta
Unit: Vikram Cement Works
Idea: Treatment of Cooling tower water without Chemicals
Email id: manoj.gupta@adityabirla.com
- Suggestion-5**
Compressed air Power Saving
Name: Shanti Prasad Sahi
Unit: Vikram Cement works
Idea: Compressed Air Saving in Bag houses

5 Nos. suggestion from TPP Function Shared at "I Love My UltraTech"

I love my UltraTech

Block your calendar to witness an exciting 76th session
04th June 2022 @ 3.00PM

Symposium Series No – 6

“AFR Consumption in TPP ”
by
North Cluster Team
Aditya | Vikram | Nathdwara

[Click here to join](#)

Thanks for Your Sincere & Kind Attention

Presented By:

Praveen Vijayvargiya

GM CPP

p.vijayvargiya@adityabirla.com

UltraTech Cement Ltd.
Vikram Cement Works
CPP