

**Welcome All**

**Date : 13.09.2023**

**Mentor : Sh. Mukesh Kumar Sinha**

**Presenting Team Members**

**Mr. Kishore Muvvala - Leader**


**Mr. Santhosh Kumar - Energy Manager**

**Mr. Neeraj Pundir - Team Member**



- **We are 8 decades young company committed in nation building.**
- **Our Group are in Cement, Sugar, Power and Refractory.**
- **We established India's first Cement Plant with 250 TPD in 1939.**
- **Overall Cement Manufacturing Capacity 43.7 MTPA**
- **Kadapa Cement Commissioned in Dec 2008 with a Capacity of 2.5MTPA Cement.**
- **The Unit usage of green fuels @ 35% TSR, 50% of Green Power**
- **The Unit is Covered with 40 % of Green Belt.**
- **The Unit is Water Positive by 7 Times with Storage Capacity of 26 Lakh KL**

# Cement Manufacturing Process



# Sp. Thermal Energy Consumption Trend & Global Comparison


**Kcal/Kg Clinker**



**Thermal SEC : 686 Kcal / Kg Clinker  
(Benchmarking Thermal SEC)**



# Sp. Thermal Energy Consumption Trend & Global Comparison





**Refuse Derived Fuel**



**Municipal Solid Waste**



**Car Interior Waste**



**Plastic Regrind Waste**



**Paper Mill Plastic Waste**









Solid Waste Feeding Extractor Capacity: 25TPH



# Covered Belt Conveyor for Solid Green Fuel Feeding







Liquid Storage Tank Capacities : 150KL

Usage Handling Capacity:100KL/Day



**Dalmia Cement (Bharat) Limited, Chinnakomerla**  
**లిక్విడ్ ఫ్యూల్ వ్యవహారాల నిర్వహణ విధానము**

క్ర. సం.	విధానం	బాధ్యత
1.	లిక్విడ్ ఫ్యూల్ కార్గో ట్రాన్స్పోర్టులో పాల్గొని వారికి ఉన్నత శిక్షణ అవసరం. అన్ని ముందుగా...	లిక్విడ్ ఫ్యూల్ కార్గో డ్రైవర్
2.	లిక్విడ్ ఫ్యూల్ కార్గో డ్రైవర్లు, ట్రాక్ ట్రాక్టర్లు మరియు ఇతర వాహనాల డ్రైవర్లు ముందుగా శిక్షణ పొందాలి.	లిక్విడ్ ఫ్యూల్ కార్గో డ్రైవర్
3.	లిక్విడ్ ఫ్యూల్ కార్గో డ్రైవర్లు, ట్రాక్ ట్రాక్టర్లు మరియు ఇతర వాహనాల డ్రైవర్లు ముందుగా శిక్షణ పొందాలి.	లిక్విడ్ ఫ్యూల్ కార్గో డ్రైవర్
4.	లిక్విడ్ ఫ్యూల్ కార్గో డ్రైవర్లు, ట్రాక్ ట్రాక్టర్లు మరియు ఇతర వాహనాల డ్రైవర్లు ముందుగా శిక్షణ పొందాలి.	లిక్విడ్ ఫ్యూల్ కార్గో డ్రైవర్
5.	లిక్విడ్ ఫ్యూల్ కార్గో డ్రైవర్లు, ట్రాక్ ట్రాక్టర్లు మరియు ఇతర వాహనాల డ్రైవర్లు ముందుగా శిక్షణ పొందాలి.	లిక్విడ్ ఫ్యూల్ కార్గో డ్రైవర్
6.	లిక్విడ్ ఫ్యూల్ కార్గో డ్రైవర్లు, ట్రాక్ ట్రాక్టర్లు మరియు ఇతర వాహనాల డ్రైవర్లు ముందుగా శిక్షణ పొందాలి.	లిక్విడ్ ఫ్యూల్ కార్గో డ్రైవర్
7.	లిక్విడ్ ఫ్యూల్ కార్గో డ్రైవర్లు, ట్రాక్ ట్రాక్టర్లు మరియు ఇతర వాహనాల డ్రైవర్లు ముందుగా శిక్షణ పొందాలి.	లిక్విడ్ ఫ్యూల్ కార్గో డ్రైవర్
8.	లిక్విడ్ ఫ్యూల్ కార్గో డ్రైవర్లు, ట్రాక్ ట్రాక్టర్లు మరియు ఇతర వాహనాల డ్రైవర్లు ముందుగా శిక్షణ పొందాలి.	లిక్విడ్ ఫ్యూల్ కార్గో డ్రైవర్
9.	లిక్విడ్ ఫ్యూల్ కార్గో డ్రైవర్లు, ట్రాక్ ట్రాక్టర్లు మరియు ఇతర వాహనాల డ్రైవర్లు ముందుగా శిక్షణ పొందాలి.	లిక్విడ్ ఫ్యూల్ కార్గో డ్రైవర్
10.	లిక్విడ్ ఫ్యూల్ కార్గో డ్రైవర్లు, ట్రాక్ ట్రాక్టర్లు మరియు ఇతర వాహనాల డ్రైవర్లు ముందుగా శిక్షణ పొందాలి.	లిక్విడ్ ఫ్యూల్ కార్గో డ్రైవర్
11.	లిక్విడ్ ఫ్యూల్ కార్గో డ్రైవర్లు, ట్రాక్ ట్రాక్టర్లు మరియు ఇతర వాహనాల డ్రైవర్లు ముందుగా శిక్షణ పొందాలి.	లిక్విడ్ ఫ్యూల్ కార్గో డ్రైవర్
12.	లిక్విడ్ ఫ్యూల్ కార్గో డ్రైవర్లు, ట్రాక్ ట్రాక్టర్లు మరియు ఇతర వాహనాల డ్రైవర్లు ముందుగా శిక్షణ పొందాలి.	లిక్విడ్ ఫ్యూల్ కార్గో డ్రైవర్
13.	లిక్విడ్ ఫ్యూల్ కార్గో డ్రైవర్లు, ట్రాక్ ట్రాక్టర్లు మరియు ఇతర వాహనాల డ్రైవర్లు ముందుగా శిక్షణ పొందాలి.	లిక్విడ్ ఫ్యూల్ కార్గో డ్రైవర్
14.	లిక్విడ్ ఫ్యూల్ కార్గో డ్రైవర్లు, ట్రాక్ ట్రాక్టర్లు మరియు ఇతర వాహనాల డ్రైవర్లు ముందుగా శిక్షణ పొందాలి.	లిక్విడ్ ఫ్యూల్ కార్గో డ్రైవర్
15.	లిక్విడ్ ఫ్యూల్ కార్గో డ్రైవర్లు, ట్రాక్ ట్రాక్టర్లు మరియు ఇతర వాహనాల డ్రైవర్లు ముందుగా శిక్షణ పొందాలి.	లిక్విడ్ ఫ్యూల్ కార్గో డ్రైవర్

**Dalmia Cement (Bharat) Limited, Chinnakomerla**  
**రసాయనముల యొక్క ప్రమాద స్వభావమును క్రింది సీంబల్స్ (గుర్తులు) తెలియజేయును.**

	స్పృశించే ప్రమాదము		తీవ్ర ప్రమాదము
	మంటలు స్పృశించే ప్రమాదము		కర్షణీయ ప్రమాదము
	మంటలు స్పృశించే ప్రమాదము		కర్షణీయ ప్రమాదము
	మంటలు స్పృశించే ప్రమాదము		కర్షణీయ ప్రమాదము
	మంటలు స్పృశించే ప్రమాదము		కర్షణీయ ప్రమాదము
	మంటలు స్పృశించే ప్రమాదము		కర్షణీయ ప్రమాదము
	మంటలు స్పృశించే ప్రమాదము		కర్షణీయ ప్రమాదము
	మంటలు స్పృశించే ప్రమాదము		కర్షణీయ ప్రమాదము
	మంటలు స్పృశించే ప్రమాదము		కర్షణీయ ప్రమాదము
	మంటలు స్పృశించే ప్రమాదము		కర్షణీయ ప్రమాదము

**Dalmia Cement (Bharat) Limited, Chinnakomerla**  
**ALTERNATIVE FUEL YARD**  
**No unauthorised entry**

**All visitors and delivery drivers must report to the site office**

**Safety helmets, safety footwear, respiratory protection and high visibility clothing must be worn at all times on this site**

**You must be safely instructed to start work on this site**

**Where eye, hand and body protection is required**

**Take care of health, safety and environment**

**LIQUID AFR STATION**

**SAFETY INSTRUCTIONS**

**1. Before starting work, read the instructions carefully.**

**2. Wear safety helmet, safety footwear, respiratory protection and high visibility clothing at all times.**

**3. Do not smoke or use open flames in the vicinity of the station.**

**4. Do not touch the equipment unless you are instructed to do so.**

**5. Do not drink or eat in the vicinity of the station.**

**6. Do not use mobile phones in the vicinity of the station.**

**7. Do not use tools or equipment unless you are instructed to do so.**

**8. Do not use the station unless you are instructed to do so.**

**9. Do not use the station unless you are instructed to do so.**

**10. Do not use the station unless you are instructed to do so.**



# Gas Bypass System





# Sp. Electrical Energy Consumption Trend (Upto Clinkerization) KWH/Ton of Clinker



# Sp. Electrical Energy Consumption Trend & Global Comparison (Overall Cement)

Units / Ton of Cement




**NB – National Benchmark**

**INB – International Benchmark**




# Sp. Electrical Energy Consumption Cement Grinding - Variety wise (kWh/Ton)


## KWH/Ton of OPC



## KWH/Ton of PPC



## Gate to Gate Energy Consumption (Kcal/Kg of Cement)





## MILESTONE



FY2023-Cooler upgradation, 4 MW Solar, RM fan impeller replacement, Pyro upgradation

**FY 2023**

**FY2022-  
Installation of 12MW  
WHRS, 16.08 MW Solar  
Plant & 15% Gas Bypass  
system**

**FY 2022**

**FY 2020 & 21**

**FY2021-Installation of  
Shredder, optimization of  
cement mill**

**FY 2020-CMBH Fan Impeller, 4 Point  
Feeding of Flyash, Cooler Optimisation**

**FY 2019**

**FY 2019 - Secondary Crusher  
Cement Mill HAG, Flyash LP Compressor**

**FY 2018**

**FY 2018 - Liquid Al. Fuel, RM Cyclone CFD &  
Modified, Clinker Cooler Modified**

**FY 2017**

**FY 2017 - Raw Mill Fan Impeller Replaced.  
Kiln Burner & Pipe Modified**

**FY 2016**

**FY 2016 - Liquid & Solid AFR  
RABH & CM Fan Impeller Replaced**

**Commissioning**

1. All Motors are Energy Efficient Series
2. More than 60% Motors are with VFD
3. All Process Fans with VFD and w/o Damper

Short term  
Long term

Replacement of Expansion Joints  
in the Pre Heater (Red. 0.6U/T)



Target - 55.9 U/T  
of  $PPC_{equ}$

4

Replacement of Raw Mill Fan with high  
efficiency impeller fan (Reduction of 1.0 U/T)

3

Cooler upgradation  
(Reduction of 1 U/T)

2

1

Installation of tertiary  
Crusher (Red. of 0.5 U/T)


Present 59.15 U/T  
of  $PPC_{equ}$



# Road Map for Achieving Benchmark / Global Best – Thermal Energy

Short term

Long term



## Major Encon Projects planned ( FY 2023 to 2024)

Sl.No.	Name of the Energy Saving Project	Investment (INR Million)	Annual Electrical Saving (Million kWh)	Annual Thermal Saving (Kcal)	Annual Savings (INR Million)
1	VFD for another compressor GA-30 Compressor	0.05	0.0036	-	0.0216
2	Reduce the power consumption of RA Fan	0	0.72	-	4.32
3	Cooler Upgradation	200	1.8	-10	10.08
4	Auto mode operation of CT fans w.r.t to cooling water temperature	0	0.0164	-	0.1084




## Summary of Energy Saving Projects in the Last 3 Years.

Year	No. of Energy saving projects	Investments (INR Million)	Electrical savings (Million kWh)	Thermal savings (Million INR)	Savings (INR Million)	Impact on SEC (kWh/MT of Cement)
2022-23	5	23.5	1.40	-	9.19	
2021-22 (GBS, WHRS, 2 Additional cooler fans)	13	1846	71.18	33.35	522.46	0.75
2020-21	21	177	6.41	6.5	134	3.69

## 5-Stage Feeding option for Increasing the power generation in PH Boiler

- Existing Preheater feeding system is six stage feeding option resulting to low PH exit temperature around 265 deg C
- The heat required for Raw mill and Coal mill drying requires the temperature around 200 deg C post WHRS
- The dust leaving the six stage feeding option will be higher when compared to 5 stage feeding option in six stage preheater



**Existing layout with  
additional Diverter**



Option	UOM	6 Stage Feeding	5 Stage feeding
Pyro Capacity	TPD	6000	6000
PH O\L Flow	Nm <sup>3</sup> /h	357500	366268
Sp. PH Fan O/L Flow	Kg/Kg Clk.	2.04	2.09
PH boiler inlet temp.	°C	265	315
PH boiler outlet Temp.	°C	140	165
Heat available from PH alone	Kcal./Kg Clk.	32.5	58.9
Power generation from PH alone	MW	2.1	3.8

## Innovative Project - 2

### Energy consumption optimization of HP BFP

Data before process optimization of HP BFP for energy saving		
PARTICULARS	UOM	PARAMETERS
TG Load	MW	9.4
Pump VFD	%	90
Current	AMP	101
Pump Discharge pressure	Kg/Cm2	27
AQC FCS CV Opening %	%	30
PH FCS CV Opening %	%	55
<b>Energy Consumption by HP BFP</b>	<b>KW</b>	<b>62</b>

Data after process optimization of HP BFP for energy saving		
PARTICULARS	UOM	PARAMETERS
TG Load	MW	9.3
Pump VFD	%	83
Current	AMP	82
Pump Discharge pressure	Kg/Cm2	23
AQC FCS CV Opening %	%	35-45
PH FCS CV Opening %	%	95
<b>Energy Consumption by HP BFP</b>	<b>KW</b>	<b>50</b>

❑ HP BFP Ratings:- 90Kw & FLC 150 Amp

❑ Following steps are done to control Auxiliary power consumption in HP BFP, are as bellow:-

❑ BFP Discharge pressure reduced from 27 kg/cm2 to 23 kg/cm2.

❑ By optimizing both AQC & PH FCS CV opening %

❑ This reduces both VFD% & Current of the pump on same load

❑ Thus in total approximately **12 Unit/Hr** energy will be saved.

❑ **8460 Unit** will be saved in month & in a year **103680 Unit** will be saved.




# Implementation of Fly ash feeding in Kiln Inlet

### Introduction:

Whenever Solid fuel tripping kiln is disturbing due to ASH & LSF Mismatch


- Solid fuel running with 25 TPH with ash around 25-28%.
- Whenever Solid is tripping LSF is increasing in raw mix and Silica is reducing. Dust circulation is increasing slowly and Kiln is coming dusty condition.
- To avoid that we introduced dry fly ash feeding directly to Kiln inlet. Dry fly ash with a quantity of 5-6 TPH due to that ash is maintaining in system and Kiln is not disturbing



#### **Introduction:**

**To feed continuously solid fuel in PC we had installed Double flap to arrest false air and stable feeding.**

- Solid fuel feeding -600 TPD
- While solid is feeding in PC, PC temperature is varying rapidly due to fluctuations in Solid feeding.
- After installation of Double flap for solid feeding, Solid fluctuations is reduced and PC temperature control.





## Renewable Energy Sources (2022-23)

Type of Renewable Energy Source	Installed Capacity in MWp	Savings	
		Energy Generated (Lakhs Unit)	Cost Saving (Rs. Lakhs)
GPP (WHRS)	12	534	3204
GPP Solar Power	16.08	220	1317
Bio Gas Plant	At Guest House	1800 m <sup>3</sup> /Yr.	1.20

Waste Heat Recovery System & Gas Bypass System two distinct enablers which is contributing for **35% green fuel** & **50% green Power**

<http://there100.org/dalmia-cement>

(page 13)

## Group Profile

Affiliations and Membership on Environment and Sustainability Domain (RE 100 )



**First Cement Plant in India Committed Voluntarily**



## knowledge speak



**Mr. Mahendra Singhi,**  
MD & CEO, Dalmia  
(Cement) Bharat LTD.

Mr. Mahendra Singhi recently engaged with EPC World, where he spoke about how Dalmia Bharat is committed to reducing carbon dioxide emissions and investing in digital technologies to transform the business.

The story talks about the implementation of newer technologies and how it has enhanced the experience of various stakeholders.

Mr. Singhi also talked about the various initiatives the organization has taken to reduce CO<sub>2</sub> emissions and its growth plans.

**Dalmia Cement Committed for Carbon Neutral by 2040**



# Dalmia Cement RE100 Committment & Action Plan

Sl.No	Description	Qty (Lakh Units/ Annum)	% of Energy Use	Remarks
1	Total Power Requirement / Consumption at Kadapa	1300	100	Annual Power Requirement
2	GPP Generation with 12 MW WHRS	600	46.2	Completed
3	16.08 MW Solar Plant within Premises	250	19.2	Completed
4	4 MW Solar	62	4.8	Completed
5	6 MW Wind	68	5.2	Under Survey
6	200MW Captive Solar(DCBL KDP Share 20MW)	320	24.6	Under Survey

**100% Energy Independence  
by 2026**

## Road Map for RE 100%

Enhancement of Existing 2 transformers from 6.8 MVA to 9.25 MVA will provide gain of 15000 KW /day .

Off site solar extension for 3MWp .

Off site Wind power of 7MWp.

M/s. Hetero Wind Power(Tirumalayapalli,30 KM from our plant) has installed 63 Wind turbine each of 1.5 MW having total capacity of 94.5 MW.

In Process of making PPA with M/s Hetero & M/sAPTRANSCO .

We will explore the possibility to get captive agreement with M/s Hetero Wind Power for long term agreement.

Sl.No	Year	Waste as Raw Material	Quantity (Tons)	Replaced material	Waste as	Total
					%	%
1	2020-21	Pond Ash	25418	Aluminus Laterite	0.84	2.16
2		Slag	28067	IronOre	0.92	
3		Red mud	12107	Aluminus Laterite & Ironore	0.4	
4	2021-22	Pond Ash	39394	Aluminus Laterite	1.64	2.06
5		Slag	2011	Aluminus Laterite & Limestone	0.08	
6		Redmud	8239	Aluminus Laterite & Ironore	0.34	
7	2022-23	Pond Ash	41755	Aluminus Laterite	1.49	3.374
8		Slag	3107	Aluminus Laterite & Limestone	0.11	
9		Redmud	34565	Aluminus Laterite & Ironore	1.24	
10		Wet Scraper Dust	5780	IronOre	0.21	
11		Tannery Sludge	911	Limestone	0.03	
12		Lime Sludge	12	Limestone	0.0004	
13		ETP Sludge	145	Limestone	0.005	
14		Boiler Ash	392	Wet Flyash	0.014	
15		Granite Dust	5287	Aluminus Laterite	0.19	
16		Iron Dust Waste Powder	2389	IronOre	0.085	



## Carbon Foot Print Activities

Year	Scope 1 emissions CO <sub>2</sub> e (MT)	Scope 2 emissions CO <sub>2</sub> e (MT)	Scope 3 emissions CO <sub>2</sub> e (MT)	kg CO <sub>2</sub> e/MT of Cement	Mitigation Total Reduction in emission intensity since baseline year study CO <sub>2</sub> e (MT)
2012 - 13 (Baseline Year)	731	70	28	829	Baseline Year
2013 - 14	722	76	24	822	7
2014 - 15	689	80	27	796	33
2015 - 16	706	77	10	793	36
2016 - 17	694	76	11	781	48
2017 - 18	698	75	13	786	43
2018 - 19	698	75	11	784	45
2019 - 20	697	74	10	781	48
2020 - 21	693	73	10	776	53
2021 - 22	686	72	10	768	61
2022 - 23	594	45	10	649	180
Target : 649 kg CO <sub>2</sub> e/MT of Cement		Process	Grid Power	Transport	Overall
					7.3% Reduction from Base Line

# Bamboo Plantation for Co2 Absorption & AFR Usage

Plantation Area : **35 Acres**





# Green Supply Chain Project (FY 2022-23)

Sl.No.	Name of Project Implemented	Investment	Benefits
1	PLMS- Plant Logistics Management System	8Lakhs	Tracking of Truck Waiting time at different Location. Auto allocation of Order
2	RFID- Radio Frequency Interface Device	7 Lakhs	Helps in Tracking of track in the Plant & TAT Reduction of Man intervention and reduction of Error Helps in Reverse Logistic
3	TBPS-Transporter Bill Payment System	5 Lakhs	Bill process time reduction Tracking of invoice status.
4	End to End Project	2 Lakhs	Goods Transition Through Godown Eliminated Goods Direct Dispatch to customer Energy & Cost Savings in Logistics
5	Vehicle up Size	-	To reduce No of trips Energy & Cost Savings in Logistics
6	DD ( Direct Dispatch)	-	Delivery to End customer to reduce handling in depots Energy & Cost Savings in Logistics
7	Conversion of diesel truck to CNG Truck	7 Lakh per truck	Environment friendly & economical
8	GPS	2K per truck	End to end tracking of truck movement, better planning, improve turn around time




## Daily Power Consumption Report

## Daily Energy Conservation Report

Dalmia Cement (Bharat) Limited. Kadapa Project Daily Power Consumption Report									
	132Kv Main Incoming Units	374595	Kwhr		Avg PF:	0.990	Report Date:	XX.06.20XX	
	DG Generation Units	0	Kwhr				Consumption Date:	XX.06.20XX	
	Peak Hour Consumption	20715	Kwhr		(MD) KVA	22500	OLT/Opn. Count	9	
Sl. No.	Section Description	Units Consumption	Running Hrs	Prod'n	Production Rate	Avg Kw	Guaranteed U/T of Matl.	Actual U/T of Matl.	
1	LS Crusher		16.17	11445	707.79	628			
	LS Crusher Main Drive	3771				233	0.38	0.33	
	LS Crusher Auxiliaries	1938				20	0.46	0.17	
	211BC2 Long Belt	2386				14	0.42	0.21	
	211BC2A Long Belt	2060				127		0.18	
	LS Crusher & Transport-Total	10155					1.25	0.89	
2	Raw Mill		16.92	7105	419.92	7106			
	Raw Mill Main Motor	6308				3733		8.89	
	Raw Mill Fan Motor	44628				2638	17.42	6.28	
	Raw Mill Classifier	152				90		0.21	
	MCC - 02 (LS Transport)	195				116		0.28	
	MCC - 03 (RM Grinding Aux.)	1936				410	2.07	0.98	
	Additive Reclaimer	327				19		0.05	
	LS Stacker & Reclaimer	1706				101		0.24	
	RM Fan SPRS Recovery	0				0		0.00	
	Total	120235					19.49	16.92	
3	Coal Mill		14.33	577	40.27	877			
	Coal Mill Main Motor	5197				363		9.01	
	Coal Mill Fan Motor	3577				250	25.51	6.20	
	Coal Mill Classifier	272				19		0.47	
	MCC - 07 (Coal Mill Grinding Aux.)	2169				151	16.73	3.76	
	RMH & Coal Crusher	1349				94		2.34	
	Total	12564					25.51	21.77	

ENERGY CONSERVATION (IDLE POWER CONSUMPTION REPORT)											
SECTION	SECTION DESCRIPTION				OPTIMUM SATURATED UP TIME	ACTUAL RUNNING HOURS	XX.06.20XX	ENERGY IN KWH			Kwh
							IDLE RUNNING TIME	IDLE /SHUT DOWN UNITS	ACTUAL U/Ton	WITHOUT IDLE RUNNING U/Ton	
LS CRUSHER	APRON FEEDER				0.00	16.17					
	CRUSHER MAIN DRIVE				0.17	17.67	1.33	106.40	0.89	0.86	80.00
	211BC2				0.50	17.92	0.00	0.00			145.00
	211BC2A				0.50	17.92	1.25	181.25			145.00
	MINES DEWATERING PUMP					66.00					
	IDLE/SHUT DOWN POWER							87.5			
	No of Start/ Stops	3.00									
Raw Mill	WEIGH FEEDER				0.00	16.92			16.92	16.88	
	MAIN DRIVE				0.03	16.90	-0.05	0.00			150.00
	FAN				0.30	16.90	-0.32	0.00			2600.00
	LS RECLAIMER FEED GROUP				12.20	16.50	4.30	335.40			78.00
	AD. RECLAIMER FEED GROUP				10.10	12.70	2.60	0.00			49.00
	TOTAL DCS IDLE / SHUT DOWN POWER							335.40			
	No of Start/ Stops	0.00	Dcs Idle Power	331.00							
Coal Mill	WEIGH FEEDER				0.00	14.33			19.44	19.06	
	MAIN DRIVE				0.03	14.40	0.04	2.00			50.00
	FAN				0.17	14.70	0.13	32.50			250.00
	COAL STACKER FEED GROUP				3.30	3.30	0.00	0.00			54.00
	COAL RECLAIMER FEED GROUP				3.80	5.30	1.50	180.00			120.00
	RAW MATERIAL HANDLING							1349.00			
	TOTAL DCS IDLE / SHUT DOWN POWER							214.50			
	No of Start/ Stops	4.00	Dcs Idle Power	75.00							

## Online SEC Monitoring by CCR Operator and taking Immediate action during increase in SEC Indication



Online SEC of Electrical & Thermal Energy Consumption as per


1. Sum of Electrical Power Consumption
2. Coal Feed Rate
3. Process Material Feed Rate

## Cloud Based Energy Management System

Grid I/C Meter



# Team Work, Employee Involvement & Monitoring





## Theme : Water Pond Development & Rain Water Harvesting



**Kadapa Plant is Water Positive**



# Employees Involvement Training – Summary (FY 2022-23)

Sl.No	Training Program	Internal / External	No.of participants	Duration (Hrs)
1	Heat & Mass Balance	Internal	12	4
2	Circulation Phenomena in Pyro Process	Virtual	13	2
3	MV Drives & SPRS-Slip Power Recovery System	External	13	4
4	Bag Filter (Over View ,operation & Maintenance)	Virtual	15	2
5	Basics of Fan Engineering	Virtual	12	3
6	Combustion Engineering	Virtual	13	2
7	Mill-Separation	Virtual	12	4
8	Motor Basics & Energy Saving	Internal	16	4

# ISO Certifications

**ISO 9001:2015**

**ISO 14001:2015**

**ISO 45001:2018**

**ISO 50001:2018**




## Turn Over & Investment

**FY 2022-23**

**Rs. 184.6 Crores, 17%**

**Rs. 1084.7 Crores**



■ Encon  
Investment



**1<sup>st</sup> Level Completed**  
**2<sup>nd</sup> Level Under Progress**



## BEE – NECA Certificate



## APSECM-Gold Award



## CII-SR Best Solid Waste Management Award



**Total 15 awards  
Received in FY  
2022-23. Include  
CII Excellence  
Award**




## Theme : Water Pond Development & Rain Water Harvesting



**Kadapa Plant is Water Positive**







# Thank you

Muvvala.Kishore@dalmiacement.com  
k.santhoshkumar@dalmiacement.com  
Pundir.Neeraj@dalmiacement.com