



Confederation of Indian Industry

24th National Award for Excellence in Energy Management 2023



JSW Energy (Barmer) Limited



Mr. Sumit Gupta



Mr. Dharmendra Kumar



Agenda

Introduction on Company

Energy Benchmarking

Innovative Projects implemented

Environment Management-
Ash Utilization

EMS System and other requirements

Any other relevant information

Energy Consumption Overview

Energy Saving projects

Utilisation of Renewable Energy

Best Practices in the Plant

NET ZERO commitment

Reward & Recognition

Introduction on Company



*Most efficient
plant in India
with CFBC
technology*

SALIENT FEATURES OF PLANT

01

Total Capacity 1080 MW (8x135MW)



02

All Units commissioned by March 2013




03

Lignite based CFBC Thermal power plant



04

Lignite sourced from Jalipa and Kapurdi mines



05


Long Term PPA with State Govt



06

Water Sourced from IGNP canal





Top in Merit
order in
Rajasthan


Plant Availability
>80%

Best Heat Rate in
CFBC in India

Operate with
CFBC Technology
for low grade
coal

- **Lowest Cost of generation** among the thermal power plant in Rajasthan.
- Total Installed Capacity 1080 MW
- JSW Energy (Barmer) Limited certified for ISO 50001:2018 (Energy Management System, ISO 9001:2015 (QMS), ISO 14001:2015 (EMS), ISO 45001:2018 (OH&SMS) & ISO 22301:2019 (BCMS).

Location of JSW Energy (Barmer) Limited



RAJASTHAN

BARMER

Unit-1
26th Nov 2009

Unit-2
04th Oct 2010

Unit-3
07th Nov 2011

Unit-4
04th Dec 2012

Unit-5
05th Feb 2013

Unit-6
03rd Mar 2013

Unit-7
16th Mar 2013

Unit-8
28th Feb 2013

JSW Energy (Barmer) COD milestones

May 2006: Implementation Agreement (IA) executed with Government of Rajasthan (GOR)

Oct 2006: PPA executed with DISCOMs for entire off take

April 2007: Commencement of project implementation

Nov 2009: First Unit achieved COD

March 2013: All units COD (Last 4 units achieved COD within 40 Days)

Energy Consumption Overview FY 23



Power Generation : 7285.66 MU



Gross Heat Rate : 2562.36 Kcal/Kwh



Plant Deemed PLF : 80.11 %



Boiler Efficiency : 80.2%



Plant Availability : 81.26 %



Turbine Heat Rate : 2055 Kcal/Kwh



Auxiliary power Consumption : 10.17%



DM Water Consump. : 2.19%







Specific oil Consumption : 0.077 ml/Kwh







Raw Water Consump. : 2474 m3/MU

Sp. Energy Consumption in last 3 years



❖ Reason for high APC is due to deterioration of Air pre heater (high sulphur content in coal), we periodically change the APH in every two year, so plan for replacement of APH in FY 24.

Energy Benchmarking




Note:

1. During the year 2020-21 the average PLF of Thermal Power Stations was 54.51 %
2. During the year 2021-22 the average PLF of Thermal Power Stations was 58.87 %

Energy Benchmarking

Roadmap



Energy Saving projects- FY 2022-23



S No	Title of Project	Annual Electrical Saving (MU)	Annual Thermal Saving (Million Kcal)	Total Annual Saving (Rs Million)	Investment (Rs Million)	Payback (Months)
1	Energy Saving by arresting APH leakages	15.43	0	69.74	43.07	7.41
2	Process Optimization in Cooling Water System by running four units with 2 CW Pump instead of 3 in winter season.	5.99	0	27.08	0	-
3	Reduction of power consumption by Stopping of 3 Nos of CT fan during winter season	3.59	0	16.25	0	-
4	Duct Interconnection between hot PA (Primary Air) Bed Gun Header and Upper SA (secondary Air) header	2.96	0	13.38	1.6	1.44
5	Installation of Energy efficient Chiller in place of VAM	1.4	0	6.31	9.12	27.8

Energy Saving projects

S No	Title of Project	Annual Electrical Saving (MU)	Annual Thermal Saving (Million Kcal)	Total Annual Saving (Rs Million)	Investment (Rs Million)	Payback (Months)
6	Reduction of Auxiliary Power Consumption of ID Fan by Slag cooler to APH Vent Modification	1.31	0	5.94	1.36	2.75
7	Removing RBF & providing direct chute in LHS	0.26	0	1.19	1.14	14.26
8	Installation of VFD in Guard Pond Pump	0.26	0	1.16	0.4	5.7
9	APC Reduction Of Air Compressor during Unit Lit-Up by providing gun atomizing from Instrument air instead of service air	0.18	0	0.83	0.08	1.16

Energy Saving projects




S No	Title of Project	Annual Electrical Saving (MU)	Annual Thermal Saving (Million Kcal)	Total Annual Saving (Rs Million)	Investment (Rs Million)	Payback (Months)
10	Installation of VFD in CMB Pump	0.05	0	0.24	0.17	8.6
11	Unit-8,Heat rate Improvement (4.2 Kcal/kwh) by HP heater internal modification	0	3990	3.52	2	6.8
12	0.4 KL Reduction in LDO consumption during Boiler Start Up.	0	225.8	1.80	0.6	4
13	Hydro Jet cleaning of boiler 2nd pass	0	1.75	1.61	0.14	1.05
Total		31.44	4218	149	60	4.83



Energy Saving projects



FY	Nos of Energy projects	Investments (INR Millions)	Electrical Saving (MU)	Thermal Saving (Million Kcal)	Saving (INR Million)
FY 2020-21	10	29.27	25.90	189.44	108.40
FY 2021-22	9	39.30	27.66	834.55	123.18
FY 2022-23	13	60	31.44	4218	149



1. Energy Efficiency Improvement Of Electric Shuttle Kiln

- **Business problem: Generation loss due to Pre mature failure of refractory**

Reason for Pre mature failure of refractory

- Uncontrolled water quality and quantity at site
- Improper material preparation
- Improper shuttering work
- Improper casting work
- Improper temperature profile along the sections during dry out process



Benefits

- Reduction of LDO Consumption : 150 KL/Year
- Cost Saving – Rs. 296.57 Lacs
- CO2 Emission Reduced – 419.49 MT
- Additional operational hours to meet out emergency requirement
- Reduce consumption of natural resources i.e. LDO

1. Energy Efficiency Improvement Of Electric Shuttle Kiln

- Pre-Dried refractory block Manufacturing Process



Mixer machine




Vibration on Vibrating Table



Vibration on Vibrating Table



Strength development & Curing



Pre-cast Brick



Storage



Electric Kiln



Final Product

2. Reduction of LDO Consumption during Cold Startup

❖ Problem:

LDO Consumption was higher during Cold Startup, which was directly impacting the plant fuel cost.

The LDO Consumption during Cold Startup in FY 20-21 was 6.3 KL

❖ Initiatives:


- Coal Inching done at bed Temperature of 300 Deg C instead of 350 Deg C
- Optimization in furnace Bed Pressure.
- LDO Burner Tip size reduced.
- LDO Burner oil pressure regulating.
- Installation of additional filter to avoid gun chocking.
- Total combustion Air flow optimization.

Average LDO Consumption reduced per Cold Startup in FY 22-23 up to **4.7** KL.

❖ Impact

LDO Consumption reduced Per lit up 1.6 KL

Monetary Saving : 72.0 Lac



3. SA & PA duct interconnection

❖ Problem



Boiler fan power consumption was higher side as fans were contributing approx 40% of total APC.

❖ Action

By providing interconnection between hot PA and hot SA header, causing SA discharge pressure reduction by Increasing total SA duct area.

❖ Impact


- Fan Power saving of 70 kW in every unit.
- Annual Energy Saving-2959.61 MWh
- Annual Monetary Saving-133.7 Lac



Utilisation of Renewable Energy



- Installation of solar rooftop of capacity 450 KW at township roof top.
- Real time monitoring of solar Generation through SOMS portal.
- As a JSW energy
 - ❑ we are adding 40 GWh / 5 GW Energy Storage by FY 2030



Environment Management- Ash Utilization



ASH MANAGEMENT


Mode of
Transportation of Ash



DRY
(Through
Bulkers)


**100% Ash
Utilization**

	UOM	2020-21	2021-22	2022-23
Ash Stock in Plant (Yard + Pond)	LMT	1.41	1.92	1.56
Ash Generated	LMT	8.89	8.97	9.11
Ash Utilization	%	102.91	94.38	103.92
Ash Utilization in manufacturing	%	72.34	68.57	69.09
Ash Utilization in FA bricks	%	19.28	23.58	30.91
Ash Utilization in Mine filling	%	8.38	7.84	0




Environment Management- Emission


CO2 Emission (MT/KWH)




SOx Emission (Mg/Nm3)



NOx Emission (Mg/Nm3)




SPM(Mg/Nm3)



Action Plan to meet the latest emission norms as per Gazette Notification

1. Modifications / Up gradation in ESP to reduce SPM level < 50 mg / Nm³




2. Enhance Lime plant capacity to control the Sox Emission


1. GHG data is submitted to Central Electrical Authority (CEA) **(Scope-1)**.
2. The data is also included in BRR (Business Responsibility Report) and available on company website for public interest.
3. Refer link : <https://www.jsw.in/investors/energy/jsw-energy-financial-information-business-responsibility-reports>

Environment Management- Water


Raw water Consumption (M3/MW)




DM Water Consumption (%)



Automation of make up water to all the tanks in plant viz. service water tank, CCW make up tank, Potable water tank, etc. so as to avoid overflowing of water



Installation of RTD in high pressure steam drain line so as to quickly identify passing of valve & attend the same



Drain & Vent temperature survey & thermography on regular intervals. Ensuring proper functioning of steam traps.



Ways to reduce DM water consumption

Environment Management- Water

Rain water Harvesting

- Rain Water Harvesting ponds are constructed inside the plant premises.
- Total Volume of Ponds= 19,200 m³



100% Effluent water Utilization

- ETP RO water is being used for DM water generation
- Cooling water and balance effluent used for plantation at plant.
- Effluent Water Treated in FY23 is 26,60,254 m³.
- Conducted **Water Audit** to identify the new areas for improving water efficiency
- Reusing of PT Plant Clarifier sludge water –**100% Utilization in Horticulture.**

DM Plant

DM Plant (Output between regeneration (OBR) improvement- from designed 18 Hrs to **20 Hrs** by installation of Online concentration analyzers & improving supervision & thus reduced regeneration & Backwash wastewater – Water savings **100 m³/Day**

Saving water through Modification in VAM Draining system

- Reroute the VAM System drain to CST Tank.
- Total water saving through this modification =**17100 m³.**

Saving water through Utilization of Condenser flood test water

- Modification has been carried for reuse of condenser flood test water.
- Total water saving through this modification =**300 m³.**

Water Conservation & Reduction in Effluent Generation through changing coagulant regime:

Initiative:

- change in coagulant regime

Benefit

- ETP Loading and further chemical treatment cost of Blowdown has been reduced approx. 23 Lac/year.
- Saving Water Cost 51.11 Lac/year by decreased CW Blow down to approx. 700 M³/day (9%)



Best Practices in the Plant-Digitization


Analytics Dash board in Qlik Sense for KPI monitoring

Digitalization of plant performance data on a single desk with the use of software Qlik sense, which collect data from DCS, Energy meters, SAP and generate daily generation reports in form of trends and graphs.



IGNITE Portal for logging improvement ideas


IGNITE portal has been launched for registering the improvement ideas by an individual.



In house Portal for inventory utilization

We set an In-House Inventory Utilization Portal common across each site of JSW Energy group.

1. Overall Non-moving Inventory can be reduced to bare minimum required.
2. Requirement of less resources to store, preserve and maintain the inventory.
3. Reduction in Obsolete Item Inventory.
4. Utilization of the obsolete items before its deterioration.




Best Practices in the Plant-Digitization

EMS Implementation


With the implementation of EMS system we have achieved following benefits:

- Real Time Comparison of APC.
- Load Monitoring of Transmission Line.
- Identify High consumption area.
- Day wise, monthly basis Report.



Performance Monitoring (OSI PI)


We have implemented OSI PI system. Through this software, we easily access the DCS parameter and facility to access the historical data for better analysis.



A wide-angle photograph of a dry, open landscape under a clear sky. The foreground is sandy with sparse, low-lying vegetation. A large, dense, dark green bush is prominent on the left. In the middle ground, several small, rounded trees are scattered across the flat terrain. The background shows a distant, hilly horizon line.




The sludge generation at pre-treatment plant is approx. 14,000MT/Year. To formation of sludge cake, centrifuge is running continuously which is consuming 37.5 KW/Hr. This waste leads to problem of handle ability while evacuation, transportation and disposal. The disposal of Sludge waste is a costly process. The poly electrolyte chemical dosing (20 Kg / day) for cake formation and transportation through tractor trolley, makes it a costly affair.




<ul style="list-style-type: none"> • Total area of plant -468 Ha
<ul style="list-style-type: none"> • Requirement of Greenbelt Development-154 Ha (as Per MOEF) (33% of Plant Area)
<ul style="list-style-type: none"> • Plantation carried out 173 Ha (MOEF compliance fulfilled) (37% of Plant Area)

Overall area covered under green belt =173 Ha

Best Practices in the Plant- Afforestation



Best Practices in the Plant- Afforestation



Best Practices in the Plant- Biodiversity

Biodiversity Assessment by CII

Floristic diversity

Total of 77 plant species were found during survey:

- Fifty tree species
- Seven grass species
- Eleven shrubs
- Nine Herbs

Faunal diversity

Total sixty three (63) species of birds have been recorded.
Resident – 49 and Mig. - 14

Major Tree/short tree species

- Khejri (Prosopis cineraria)
- Meetha Jaal (Salvadora Persica)
- Khara Jaal (Salvadora oleoides)
- Prosopis juliflora
- Neem (Azadirachta indica)
- Desi babool (Acacia nilotica)


Major shrub and herb species

Shrubs

- Euphorbia caducifolia
- Kheep (Leptadelia pyrotechnica)
- Ziziphus nummularia
- Akda (Calotropis procera)

Herbs

- Choti bui (Aerva javanica)
- Badi bui (Aerva persica)
- Saniya (crotolaria burhia)
- Tephrosia spp.
- Argemone maxicana



Best Practices in the Plant- Maintenance & reliability

Turbine Front pedestal in house correction to improve RH Temp.



Before



After

HP Heater internal correction to improve FW temp.

After removed bundle of heater and after inspection its observed that many holes found of inside chamber of sub cooling zone. After correction FW temp. raised by 5 deg C resulting in improvement in Heat rates



BFP Booster pump refurbishment to improve pump efficiency

In house refurbishment of booster pump of boiler feed pump to improve the pump efficiency. Power consumption of BFP has reduced by 10 KW.



EMS System and other requirements

EMS Implementation

With the implementation of EMS system we have achieved following benefits:

- Real Time Comparison of APC.
- Load Monitoring of Transmission Line.
- Identify High consumption area.
- Day wise, monthly basis Report.

OCA01	OCA03	OCB01	OCB03	GENERATOR	HCSD/STORE SOLAR
1CA01	3CA01	5CA01	7CA01	UAT	DM/MMD SOLAR
1CA02	3CA02	5CA02	7CA02	GENERATOR TRANSFORMER	
OCA02	OCA04	OCB02	OCB04	STATION TRANSFORMER	
2CA01	4CA01	6CA01	8CA01	220/400 KV LINE	
2CA02	4CA02	6CA02	8CA02	GENERATOR HOME	

ISO 50001:2018 Certified



Bureau Veritas Certification

JSW ENERGY(BARMER) LIMITED



VILLAGE/POST : BHADRESH, DIST. : BARMER - 344 001, RAJASTHAN, INDIA.

Bureau Veritas (India) Pvt. Ltd. (Certification Business) certify that the Management System of the above organisation has been audited and found to be in accordance with the requirements of the management system standards detailed below

Standard

ISO 50001:2018

Scope of certification

GENERATION OF ELECTRICITY THROUGH OPERATION OF LIGNITE BASED THERMAL POWER PLANT

Original cycle start date: 10 December 2017

Expiry date of previous cycle: 09 December 2020

Recertification Audit date: 11 November 2020

Recertification cycle start date: 10 December 2020

Subject to the continued satisfactory operation of the organization's Management System, this certificate expires on: 09 December 2023

Certificate No. IND.20.9107/EN/N Version : 1 Revision date: 07 December 2020


Certification Authority
Jagdheesh N. MANIAN
Head - CERTIFICATION, South Asia
Commodities, Industry & Facilities Division



Local office: Bureau Veritas (India) Private Limited (Certification Business)
72 Business Park, Marol Industrial Area, MIDC Cross Road "C",
Andheri (East), Mumbai - 400 093, India.

Further clarifications regarding the scope of this certificate and the applicability of the management system requirements may be obtained by consulting the organization.
To check the certificate validity please call +91 22 6274 2056.

Energy Audit by CII

Performance Gap analysis has been conducted by CII Team in FY 23.



NET ZERO commitment- Sustainability



17 Focus Areas with 2030 Targets from 2020 as Base Year



Climate Change:

Committed to being carbon neutral by 2050
Reduce our carbon emissions by more than 50%



Biodiversity: No Net Loss for Biodiversity



Waste Water: Zero Liquid Discharge



Water Resources: Reduce our water consumption per unit of energy produced by 50%



Waste : 100% Ash (Waste) utilization



Resources



Employee Wellbeing



Social Sustainability



Local Considerations



Indigenous People



Human Rights



Supply Chain Sustainability



Health & Safety



Air Emissions



Business Ethics



Cultural Heritage



Energy

Sustainability: Framework and Priorities

Governance & Oversight by Sustainability Committee

2

Independent Directors

Mr. Sunil Goyal

Ms. Rupa Devi Singh

1 Executive Director

Mr. Prashant Jain

ESG Ratings

MSCI



BB



A- (Leadership Level)

Carbon Neutrality by 2050



Committed to set science based targets to keep global warming to 1.5°C under SBTi

Competency & Problem Solving

Energy Efficiency Training & Awareness Programs

No. of
Participants

Duration
(mandays)

Internal

125

3.25

External

75

1.25

Projects Implemented through KAIZENS

Raised

Implemented

Supervisors

80

80


- **14 QC** teams for *continuous improvement projects under KAIZEN*.
- **Energy Management Cell** – Core team along with Support team formed with objective of improvement projects for *energy conservation*.

First MoM of Performance Optimization Group		Location :	VC with VINGER / RTNG / HBPL / RWPL	
Date:	3-Aug-20	Time :	10:30 hrs to 11:30 hrs	
Members Present: Mr.Gyan Brahma Kumar, Mr.Ajay Agarwal, Mr.Shantharam Patil, Mr.Rajesh Vasudevan, Mr.Sudhakar Mahi, Team VINGER leading by Mr.Karthikeya Ware, Team RTNG leading by Mr.Vijay John, Team HBPL leading by Mr.Ajay Koth, Team RWPL leading by Mr.V.Reddy				
Sr. No.	Details of Discussion	Action by Location	Responsibility	Status
1	Monthly given need to be worked for all the performance activities which are completed	All Stations	Station Engineer	POG's
2	Cooling Tower and Condenser performance need to be Ruzmagi/measure. All letters for reducing losses need to be shared with Vinyanaga/Corporate along with supporting documents	Barmer	POG Heat Rate Team	
3	Issues related to measuring of Efficiency of CW Pumps / SWP/Plantwater/ need to be discussed with professors from IIT Mumbai	Barmer	Team Calcutta	
4	Therms of Hydro Turbine performance with parameters like water inlet flow, generation, as per core opening, etc. need to be recorded on regular frequency		POG Team	
5	SPU-2, J1 & 2 defects need to be addressed before taking into service	Vinyanaga	Head O&M VINGER	
6	Protocol for scaffolding need to be stored among the Barmer/locations	Vinyanaga	POG Heat Rate Team	
7	RI Conveyor (Vessel discharge) connected load cell instrument something to be arranged and to be taken up with the port for thorough investigation		RTNG POG Coal Team	
8	Issues related to performance deteriorates on after COH need to be taken up with Sciences / Alchem	Vinyanaga	POG Heat Rate Team	
9	Part wise categorization of performance issues need to be taken out based on critical monetary impact	All Stations	POG Team	
Workings of various process stations need to be reviewed				

POG teams

POG teams

- **Cross functional teams** formed at plant level to work for improvement in performance parameters viz. GHR, APC, O&M Cost etc
- Review meetings chaired by HoP & HoT



4i-J2 & J3 Projects

- Identified & trained 27-J2 candidates & 8-J3 candidates to work for a cross functional project involving high end statistical tools & analysis
- The projects adopts our unique **4i** improvement methodology (Identify, Ideate, Implement, Institutionalize)

Calibration of Energy Conservation Week



- **Energy Conservation Week** is celebrated every year in the form of various competitions and activities with involvement of company employees, associate employees.



Reward & Recognition



“NECA Award 2020 in Energy Conservation”
Organized by Government of India



“9th FICCI Quality Systems Excellence Award” for Quality Organised by Federation of Indian Chambers of Commerce and Industry.



JSWBL achieved “Five Star grading & sword of Honor in Occupational Health and Safety Audit conducted by the British Safety Council”



“National Efficiency Award – 2023” for Best Energy Efficient Plant-Lignite by Mission Energy Foundation.



“Gold Award 2022 in Sustainability”
Organized by Grow Care India



THANK YOU